

# Complete surface-mounted flat distribution board, white, 24 SU per row, 5 rows, type A

Powering Business Worldwide

Part no. BF-0-5/120-A Article no. 240735

<b>D</b>			
	IVAL	, nro	gram
ישע	IIVGIN	/ DIU	ulalli

Basic function			Basic device
Product function			Installation distribution boards
Product range			BF flat DBO
Design			Surface mounted
Installation site			Indoor
Type of installation			Surface mounting
Door/Flap			White
Degree of Protection			IP30
Colour			White
Module rack			Rail-frame
Shroud for protection against accidental contact			Metal
Rows	Count		5
Module units per row			24
Description			IP30 Protection Class I Steel sheet enclosure white (RAL 9016)
Cable entries			Cable entries on top and bottom
PE and N terminals design			Screw terminals
PE and N terminals	Number x cross- sectional area	mm <sup>2</sup>	N: 2 x 25 + 9 x 16 PE: 2 x 25 + 58 x 16
Equipment supplied			Enclosure Door with three-point turn-lock DIN rail mounting frame Cable gland plate inserts (top) Front plates Neutral-/protective conductor terminal

#### **Technical data**

#### General

Standards			IEC/EN 61439-1, IEC/EN 61439-3, IEC/EN 62208
RoHS (in accordance with Directive 2002/95/EC of the European Parliament and Council)			conform
Ambient temperature		°C	-5 - +40
Degree of Protection			IP30
Protection class			I (earthed)
Rated operational voltage	Ue	V AC	415
Rated frequency	f	Hz	50/60
Material characteristics			
Material			Sheet steel, powder-coated
Colour			white (RAL 9016)
Material properties			
Mechanical			
Impact resistance			IK07

# Design verification as per IEC/EN 61439

Technical data for design verification			
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890			
Individual enclosure for wall mounting	$P_{V}$	CO	59
Starting enclosure for wall mounting	$P_{V}$	CO	56
Middle enclosure for wall mounting	$P_{V}$	CO	53

Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees, calculated as per IEC 60890  Individual enclosure for wall mounting Py CO 118  Starting enclosure for wall mounting Py CO 112  Middle enclosure for wall mounting Py CO 107  /EN 61439 design verification  10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects
Starting enclosure for wall mounting  Pv C0 112  Middle enclosure for wall mounting  Pv C0 107  /EN 61439 design verification  10.2 Strength of materials and parts 10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat  Meets the product standard's requirements.  Meets the product standard's requirements.  Meets the product standard's requirements.  Meets the product standard's requirements.
Middle enclosure for wall mounting  Py CO 107  Let N 61439 design verification  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat  Meets the product standard's requirements.
/EN 61439 design verification  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.
10.2 Strength of materials and parts  10.2.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.
10.2.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3.2 Verification of resistance of insulating materials to normal heat  Meets the product standard's requirements.  Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3.2 Verification of resistance of insulating materials to normal heat  Meets the product standard's requirements.  10.2.3.3 Verification of resistance of insulating materials to abnormal heat  Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat  Meets the product standard's requirements.  Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat  Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Not relevant to indoor installations.
10.2.5 Lifting Does not apply to enclosures without lifting aids.
10.2.6 Mechanical impact IK07
10.2.7 Inscriptions Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES IP30
10.4 Clearances and creepage distances Is the panel builder's responsibility.
10.5 Protection against electric shock $< 0.1 \Omega$ ; meets the product standard's requirements.
10.6 Incorporation of switching devices and components Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections Is the panel builder's responsibility.
10.8 Connections for external conductors Is the panel builder's responsibility.
10.9 Insulation properties
10.9.2 Power-frequency electric strength $U_i = 415 \text{ V AC}$
10.9.3 Impulse withstand voltage Does not apply to basic enclosures as defined in EN 62208.
10.9.4 Testing of enclosures made of insulating material Does not apply to metal enclosures.
10.10 Temperature rise  The panel builder is responsible for the temperature rise calculation. Eator provide heat dissipation data for the devices.
10.11 Short-circuit rating Is the panel builder's responsibility.
10.12 Electromagnetic compatibility Is the panel builder's responsibility.
10.13 Mechanical function Meets the product standard's requirements.


## **Technical data ETIM 6.0**

Distribution boards (EG000023) / Small distribution board (EC000214)

Electric engineering, automation, process control engineering / Electrical installation, device / Electrical distribution system (incl. small distribution board) / Small distribution board (ecl@ss8.1-27-14-24-09 [ACN387008])

(ECI@550.1-27-14-24-03 [ACN307000])		
Mounting method		Surface mounting
Number of rows		5
Width in number of modular spacings		24
Type of cover		Door
Cover model		Closed
Transparent cover/door		No
Material housing		Steel
Height	mm	900
Width	mm	543
Depth	mm	140
Built-in depth	mm	140
Internal depth	mm	131
DIN-rail		Yes
With mounting plate		No
Extension possible		No
EMC-version		No
Colour		White
RAL-number		9016
Degree of protection (IP)		IP30
With lock		No

## **Dimensions**



# **Additional product information (links)**

Product overview (Web)

http://www.eaton.eu/DE/Europe/Electrical/ProductsServices/Residential/index.htm