

RCD/MCB combination switch, 20A, 100mA, miniature circuit-br. type B trip characteristic, 1-phase+N, residual current circuit-br. trip characteristic: A



Part no. Article no. Catalog No.

FRBMM-B20/1N/01-A 170668 FRBMM-B20/1N/01-A

Similar to illustration

Delivery program Basic function Combined RCD/MCB devices 1 pole+N Number of poles В Tripping characteristic Application Switchgear for industrial and advanced commercial applications Rated current 20 ١_n А Rated switching capacity according to IEC/EN 61009 kA 10 Rated fault current А 0.1 $I_{\Delta N}$ Tripping А non-delayed Product range FRBmM Pulse-current sensitive Sensitivity Impulse withstand current Partly surge-proof 250 A Contact sequence Ν

Technical data

| Electrical | | | |
|-------------------------|----|---|-------------------------|
| Sensitivity | | | Pulse-current sensitive |
| Rated current | In | А | 20 |
| Tripping characteristic | | | В |

Design verification as per IEC/EN 61439

| Design vernication as per icc/civ 01459 | | | |
|------------------------------------------------------------------------------------------------------------------------|-------------------|----|--------------------------------------------------------------------|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | I _n | А | 20 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 5.4 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 40 |
| | | | 0 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |

| 10.2.7 Inscriptions | Meets the product standard's requirements. |
|----------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

Circuit breakers and fuses (EG000020) / Earth leakage circuit breaker (EC000905)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / MCB/RCCB combination (ecl@ss8.1-27-14-22-07 [AFZ810012])

| Number of poles (total) | | 2 |
|---------------------------------------------------|----|-------|
| Number of protected poles | | 1 |
| Nominal rated voltage | V | 240 |
| Nominal rated current | А | 20 |
| Rated fault current | А | 0.1 |
| Leakage current type | | A |
| Current limiting class | | 3 |
| Rated short-circuit breaking capacity EN 60898 | kA | 10 |
| Rated short-circuit breaking capacity IEC 60947-2 | kA | 0 |
| Frequency | | 50 Hz |
| Release characteristic | | В |
| Concurrently switching N-neutral | | Yes |
| Over voltage category | | 3 |
| Pollution degree | | 2 |
| Width in number of modular spacings | | 2 |
| Built-in depth | mm | 75.5 |
| Suitable for flush-mounted installation | | No |
| Degree of protection (IP) | | IP20 |
| Surge current capacity | kA | 0.25 |
| Voltage type | | AC |
| Antinuisance tripping version | | No |

Dimensions

