

RCD/MCB combination switch, 25A, 300mA, miniature circuit-br. type B trip characteristic, 1-ph+N, residual current circuit-br. trip characteristic:



Part no. FRBMM-B25/1N/03-G Article no. 170558 Catalog No. FRBMM-B25/1N/03-G

Similar to illustration

| D - I | | | |
|-------|--------|-----|------|
| IJel | livery | nro | ıram |
| | | | |

| Delivery program | | | |
|--|----------------|----|--|
| Basic function | | | Combined RCD/MCB devices |
| Number of poles | | | 1 pole+N |
| Tripping characteristic | | | В |
| Application | | | Switchgear for industrial and advanced commercial applications |
| Rated current | In | Α | 25 |
| Rated switching capacity according to IEC/EN 61009 | | kA | 10 |
| Rated fault current | $I_{\Delta N}$ | Α | 0.3 |
| Tripping | | Α | Short time-delayed |
| Product range | | | FRBmM |
| Sensitivity | | | AC current sensitive |
| Impulse withstand current | | | Surge-proof, 3 kA |
| Contact sequence | | | |

Technical data

Electrical

| Sensitivity | | | AC current sensitive |
|-------------------------|----|---|----------------------|
| Rated current | In | Α | 25 |
| Tripping characteristic | | | В |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 25 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 5 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 40 |
| | | | 0 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3Verification of resistanceofinsulatingmaterialstoabnormalheatandfireduetointernalelectriceffects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | | |

| 10.2.7 Inscriptions | Meets the product standard's requirements. |
|--|--|
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

Voltage type

Antinuisance tripping version

Circuit breakers and fuses (EG000020) / Earth leakage circuit breaker (EC000905)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / MCB/RCCB combination (ecl@ss8.1-27-14-22-07)

[AFZ810012]) 2 Number of poles (total) Number of protected poles 1 ٧ 240 Nominal rated voltage Nominal rated current Α 25 Rated fault current Α 0.3 AC Leakage current type Current limiting class 3 Rated short-circuit breaking capacity EN 60898 kA 10 kA Rated short-circuit breaking capacity IEC 60947-2 0 Frequency 50 Hz Release characteristic В Concurrently switching N-neutral Yes Over voltage category 3 2 Pollution degree 2 Width in number of modular spacings Built-in depth 75.5 mm No Suitable for flush-mounted installation IP20 Degree of protection (IP) Surge current capacity kA 10

AC

Yes

Dimensions

