

Residual current circuit breaker (RCCB), 80A, 4p, 300mA, type G/F



Part no. Article no. FRCMM-80/4/03-G/F 187423

Similar to illustration

Delivery program			
Basic function			Residual current circuit breakers
Number of poles			4 pole
Rated current	In	А	80
Rated short-circuit strength	I <sub>cn</sub>	kA	10 with back-up fuse
Tripping		А	10 ms delayed
Product range			FRCmM
Sensitivity			Pulse-current sensitive

## **Technical data**

		IEC/EN 62423
		As per inscription
	А	10 ms delayed
Un	V AC	240/415
f	Hz	50
	V AC	196 - 456
$I_{\Delta n}$	mA	300
		Pulse-current sensitive
		Frequency mix (10 Hz, 50 Hz, 1000 Hz)
Ui	V	440
U <sub>imp</sub>	kV	4 (1.2/50μs)
I <sub>cn</sub>	kA	10 with back-up fuse
		3 kA (8/20 μs) surge-proof
gG/gL	А	80
gG/gL	А	80
I <sub>m</sub> / I <sub>∆m</sub>	А	800
	Operation	10000
	mm	45
	mm	80
	mm	70 (4TE)
		Quick attachment with 2 latch positions for DIN-rail IEC/EN 60715
		IP20 switches IP 40 enclosed
		Twin-purpose terminals
		Busbar tag shroud to BGV A3, ÖVE-EN 6
	mm <sup>2</sup>	1.5 - 35
	mm <sup>2</sup>	2 x 16
		M5 (with cross-recessed screw as defined in EN ISO 4757-Z2, Pozidriv PZ2)
		IND (WILL CLOSS-LECESSED SCIEW AS DELITED IT EN ISO 4757-22, FUZIULIV F22)
	f I∆n Ui Uimp Icn gG/gL gG/gL	Un V AC   f Hz   I V AC   I MA   I V   Ui V   I V   I V   I V   I V   I V   I OP   I OP   I OP   I MM   I MM

Thickness of busbar material	mm	0.8 - 2
Admissible ambient temperature range	°C	-25 - +40
Permissible storage and transport temperatures	°C	-35 - +60
Climatic proofing		according to IEC/EN 61008
Mounting position		As required
Contact position indicator		red / green
Trip indication		white / blue

## Design verification as per IEC/EN 61439

Design vermeation as per 120/214 01405			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	А	80
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	18.8
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 6.0**

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss8.1-27-14-22-01 [AAB906011])		
Number of poles		4
Nominal rated voltage	V	240
Nominal rated current	А	80
Rated fault current	А	0.3
Mounting method		DIN rail
Leakage current type		-

Selective protection		No
Short-circuit breaking capacity (Icw)	kA	10
Surge current capacity	kA	3
Frequency		50 Hz
Additional equipment possible		Yes
Degree of protection (IP)		IP20
Construction size (in accordance with DIN 43880)		1
Width in number of modular spacings		4
Built-in depth	mm	70.5
Short-time delayed tripping		Yes