

Circuit-breaker, 3 pole, 1000 A, 85 kA, Selective operation, IEC, Fixed

Powering Business Worldwide[™]

Part no. IZMX40N3-V10F-1 Article no. 183711

Delivery program

zonro., program			
Product range			Air circuit-breakers/switch-disconnectors
Product range			Open circuit-breakers
Current Range			Up to 4000 A
Protective function			Selective operation
Installation type			Fixed
			Main terminals must be separately ordered.
Construction size			IZMX40
Release system			Electronic release
Standard/Approval			IEC
Number of poles			3 pole
Degree of Protection			IP31 with door seals, IP55 with protective cover
			suitable for zone selectivity optionally fittable by user with comprehensive accessories
Rated current = rated uninterrupted current	$I_n = I_u$	Α	1000
up to 440 V 50/60 Hz	I _{cu}	kA	85
up to 440 V 50/60 Hz	I _{cs}	kA	85
Overload release, min.	Ir	Α	400
Overload release, max.	I _r	Α	1000
Non-delayed	$I_i = I_n x \dots$		2 - 15, OFF
Delayed X >	$I_{sd} = I_r x \dots$		1,5 - 10

Technical data

Rated uninterrupted current at 60 °C Rated uninterrupted current at 70 °C

		IEC/EN 60947
9	°C	-20 - +70
	°C	-20 - +70
		30° 30°
		30° 30°
		В
		IP31 with door seals, IP55 with protective cover
		as required
$I_n = I_u$	Α	1000
Iu	Α	1000
	$I_n = I_u$	$I_n = I_u$ A

 $\mathbf{I}_{\mathbf{u}}$

Α

1000

1000

Rated impulse withstand voltage	U_{imp}	V AC	12000
Rated operational voltage	U _e	V AC	690
Use in IT electrical power networks up to U = 440 V	I _{IT}	kA	0
Use in IT electrical power networks up to U = 690 V	I _{IT}	kA	0
Overvoltage category/pollution degree			III/3
Rated insulation voltage	Ui	٧	1000
Switching capacity			
Rated short-circuit making capacity	I _{cm}		
up to 440 V 50/60 Hz	I _{cm}	kA	187
up to 690 V 50/60 Hz	I _{cm}	kA	166
Rated short-time withstand current 50/60 Hz			
t=1s	I _{cw}	kA	85
t=3 s	I _{cw}	kA	66
Rated short-circuit breaking capacity I _{cn}	I _{cn}		
IEC/EN 60947 operating sequence I _{cu} 0-t-C0			
up to 240 V 50/60 Hz	I _{cu}	kA	85
up to 440 V 50/60 Hz	I _{cu}	kA	85
up to 690 V 50/60 Hz	I _{cu}	kA	75
IEC/EN 60947 operating sequence I _{cs} 0-t-C0-t-C0	Cu		
up to 240 V 50/60 Hz	I _{cs}	kA	85
up to 440 V 50/60 Hz		kA	85
	I _{cs}		
up to 690 V 50/60 Hz	I _{cs}	kA	75
Operating times			ar.
Closing delay via spring release Total opening delay via shunt release		ms	35 35
Total opening delay via shunt release Total opening delay via undervoltage release		ms	40
total opening delay via undervoltage release		ms	40
Total opening delay on non-delayed short-circuit release (up to complete arc quenching)		ms	52
Lifespan		S	
Lifespan, mechanical	Switching cycles (ON/ OFF)		12500
Lifespan, mechanical with maintenance	Switching cycles (ON/ OFF)		25000.
Lifespan, electrical	Switching cycles (ON/ OFF)		10000
Lifespan, electrical with maintenance	Switching cycles (ON/ OFF)		20000.
Maximum operating frequency	Operations/h		60
Heat dissipation at rated current I _n			
Fixed mounting		W	40
Weight			
Fixed mounting			
3-pole		kg	43
Terminal capacities			
Copper bar			
Fixed mounting Black		mm	1 x 60 x 10
ыаск		mm	These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide specific and detailed information.
			sectional area. Temperature rise tests in the specific switchgear can provide

Design verification as per IEC/EN 61439

· · · · · · · · · · · · · · · · · · ·			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	1000
Equipment heat dissipation, current-dependent	P _{vid}	W	40
Operating ambient temperature min.		°C	-20
Operating ambient temperature max.		°C	70
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation prot. (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss8.1-27-37-04-09 [AJZ716010])

Rated voltage Noterload release current setting A 500 - 1000 Adjustment range short-term delayed short-circuit release Adjustment range undelayed short-circuit release A 2000 - 10000 Adjustment range undelayed short-circuit release A 2000 - 12000 Integrated earth fault protection No Type of electrical connection of main circuit Device construction Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional No No No No No No No No No N			
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz kA 85 Diverload release current setting A 500 - 1000 Adjustment range short-term delayed short-circuit release A 2000 - 10000 Adjustment range undelayed short-circuit release A 2000 - 12000 Integrated earth fault protection No Type of electrical connection of main circuit Device construction Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional No No Number of auxiliary contacts as normally open contact Number of auxiliary contacts as normally open contact Na 85 2000 - 10000 A 2000 - 12000 No Rail connection Built-in device fixed built-in technique No No No No No No No No No N	Rated permanent current lu	А	1000
Overload release current setting A 500 - 1000 Adjustment range short-term delayed short-circuit release A 2000 - 10000 Adjustment range undelayed short-circuit release A 2000 - 12000 Integrated earth fault protection No Type of electrical connection of main circuit Oevice construction Built-in device fixed built-in technique No OIN rail (top hat rail) mounting optional No No Number of auxiliary contacts as normally open contact No Number of auxiliary contacts as normally open contact Overload release current setting A 500 - 1000 A 2000 - 12000 No	Rated voltage	V	690 - 690
Adjustment range short-term delayed short-circuit release Adjustment range undelayed short-circuit release A 2000 - 12000 No Type of electrical connection of main circuit Device construction Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional No No No No No No No No No N	Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	85
Adjustment range undelayed short-circuit release A 2000 - 12000 Integrated earth fault protection No Rail connection Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional No Number of auxiliary contacts as normally open contact A 2000 - 12000 Number of auxiliary contacts as normally open contact A 2000 - 12000 Number of auxiliary contacts as normally open contact A 2000 - 12000 Number of 2000 - 1	Overload release current setting	Α	500 - 1000
ntegrated earth fault protection No Rail connection Built-in device fixed built-in technique No DIN rail (top hat rail) mounting optional No No No No No No No No No N	Adjustment range short-term delayed short-circuit release	Α	2000 - 10000
Figure of electrical connection of main circuit Device construction Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional No Number of auxiliary contacts as normally open contact Number of auxiliary contacts as normally open contact Number of auxiliary contacts as normally open contact Name of auxiliary contacts as normally open contact Name of auxiliary contacts as normally open contact No Number of auxiliary contacts as normally open contact Number of auxiliary contacts as normally open contact	Adjustment range undelayed short-circuit release	Α	2000 - 12000
Device construction Built-in device fixed built-in technique No DIN rail (top hat rail) mounting optional No Number of auxiliary contacts as normally open contact O Number of auxiliary contacts as normally open contact O	Integrated earth fault protection		No
Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally closed contact O Number of auxiliary contacts as normally open contact O	Type of electrical connection of main circuit		Rail connection
No Number of auxiliary contacts as normally open contact O Number of auxiliary contacts as normally open contact O	Device construction		Built-in device fixed built-in technique
Number of auxiliary contacts as normally closed contact 0 Number of auxiliary contacts as normally open contact 0	Suitable for DIN rail (top hat rail) mounting		No
Number of auxiliary contacts as normally open contact 0	DIN rail (top hat rail) mounting optional		No
	Number of auxiliary contacts as normally closed contact		0
Number of auxiliary contacts as change-over contact 2	Number of auxiliary contacts as normally open contact		0
	Number of auxiliary contacts as change-over contact		2

Switched-off indicator available	Yes
With under voltage release	No
Number of poles	3
Position of connection for main current circuit	Back side
Type of control element	Push button
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	Yes
Degree of protection (IP)	IP31

Dimensions

