

Part no. Article no. NZM4-4-XKVI1P 180019



Delivery program

Number of poles			1 pole	
Accessories			DC link kit	
Number of conductors			4	
			Jumper kit with insulating plates, phase isolators IP00 and heat sinks	
Rated current	In	A	1260 (40 °C,) 1138 (65 °C)	
For use with			N4-4-(800)(1000)(1250)(1400)-S1(-S15)-DC N4-4S1(-S15)-PV-NA	
Notes				
Model contains parts for upper switch side for 4 pole switches NDC that are used as 1 pole switches for DC.				
The links each connect contacts in series.				

Incoming unit and outgoer at bottom or top, user-definable.

See figure connection type.

Design verification as per IEC/EN 61439

IEC/EN 61439 design verification	
10.2 Strength of materials and parts	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss8.1-27-37-04-24 [ACN957008])			
Suitable for number of poles	1		
Model			

Approvals

Product Standards	UL 489B; IEC 60947-3; CE marking
UL File No.	E471671
CSA File No.	· · · · · · · · · · · · · · · · · · ·
CSA Class No.	· · · · · · · · · · · · · · · · · · ·
North America Certification	UL listed
Current Limiting Circuit-Breaker	No
Max. Voltage Rating	1500 VDC
Degree of Protection	IEC: IP20; UL/CSA Type: -

Dimensions

