

Auxiliary contact, 1N/O+1N/C, for QM40/63

QMAUX1NO+1NC40/63 1319851



Delivery program

Product range	Accessories
Part group reference	QM
Basic function	Auxiliary contact
	Switching duty 6 A, 230 V AC
Contacts	
N/O = Normally open	1 N/O
N/C = Normally closed	1 NC
For use with	QM40 QM63

Design verification as per IEC/EN 61439

Part no.

Article no.

Technical data for design verification Rated operational current for specified heat dissipation Heat dissipation per pole, current-dependent Pod W 0.1 Static heat dissipation, non-current-dependent Pod W 0.5 Static heat dissipation, non-current-dependent Pod W 0.5 Static heat dissipation, current dependent Pod W 0.5 Static heat dissipation, non-current-dependent Pod W 0.5 Static heat dissipation capacity Pod W 0.5 Static heat dissipation did with per dissipation did heat for the devices. Static heat d	Design vermoation as per illo/liv 01433			
Heat dissipation per pole, current-dependent P _{vid} W 0.11 Equipment heat dissipation, current-dependent P _{vid} W 0. Static heat dissipation, current-dependent P _{vid} W 0. Static heat dissipation, current-dependent P _{vid} W 0. ECEN 61439 design verification 10.2 Strongfix of materials and parts 10.2.2 Corrosion resistance 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of resistance of insulating materials to abnormal heat 10.2.5 Verification of v	Technical data for design verification			
Equipment heat dissipation, current-dependent P _{vs} W 0 Static heat dissipation, non-current-dependent P _{vs} W 0 Heat dissipation capacity P _{diss} W 0 ECEN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3 Verification of thermal stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.9 Open of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Insulation properties 10.9.1 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Insulation properties 10.9.1 The panel builder's responsibility. 10.9.3 Insulation properties 10.11 Short-circuit rating 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.10 Temperature rise 10.11 Mechanical function 10.12 Electromagnetic compatibility 10.10 Mechanical function 10.10 Mechanical function 10.10 Mechanical function 10.10 Heave meets the requirements, provided the information in the instruction of switchgear must observed. 10.10 Heave meets the requirements of the switchgear must observed. 10.10 Heave meets the product standard's requirements. 10.11 Heave meets the product standard's requirements. 10.12 Heave meets the product standard's requirements. 10.13 Mechanical function 10.14 Heave meets the product standard's requirement	Rated operational current for specified heat dissipation	In	Α	6
Static heat dissipation, non-current-dependent Pas W 0 Heat dissipation capacity Pdiss W 0 ECEN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Effection apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and components 10.8 Connections for external conductors 10.9 Insulation properties 10.9 Insulation properties 10.9 Insulation properties 10.9 A Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Heat dissipation per pole, current-dependent	P _{vid}	W	0.11
Heat dissipation capacity EC/EN 61439 design verification 10.2.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.5 Incorporation of switching devices and components 10.7 Inscriptions 10.8 Connections for external conductors 10.9 Insulation properties 10.9 Power-frequency electric strength 10.9 Insulation properties 10.9 Testing of enclosures made of insulating material 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Internal electric shock 10.18 Incorporation of switching devices and components 10.19 Insulation properties 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. Meets t	Equipment heat dissipation, current-dependent	P _{vid}	W	0
EE/EN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3. Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgar needs to be evaluated. 10.2.5 Inscriptions Meets the product standard's requirements. 10.3.0 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgar needs to be evaluated. 10.3.0 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgar needs to be evaluated. 10.4.0 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgar needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgar needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgar needs to be evaluated. 10.8 Incurrence Sometime of the entire switchgar needs to be evaluated. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Insulation properties	Static heat dissipation, non-current-dependent	P _{vs}	W	0
EC/EN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Litting 10.2.6 Meets the product standard's requirements. 10.2.5 Litting 10.2.6 Meets the product standard's requirements. 10.2.7 Inscriptions 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Egree of protection of ASSEMBLIES 10.3.0 Egree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Incorporation of switching devices and components 10.5 Incorporation of switching devices and components 10.5 Incorporation of switching devices and components 10.8 Connections for external conductors 10.9 Insulation properties 10.9.1 Power-frequency electric istrength 10.9.2 Power-frequency electric istrength 10.9.3 Impulse withstand voltage 10.1 Sthe panel builder's responsibility. 10.10 Temperature rise 10.10 Thermal electrication of insulating material 10.10 Temperature rise 10.10 Temperature rise sponsibility. 10.2.2 Insulation properties 10.3 Impulse withstand voltage 10.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.4 Testing of enclosures made of insulating material 10.10 Temperature rise sponsibility. 10.2.1 Electromagnetic compatibility 10.3.1 Electromagnetic compatibility 10.1.2 Electromagnetic compatibility 10.1.3 Mechanical function 10.10 Meets the product standard's requirements. 10.10 Temperature rise calculation. Eaton will provide the active switchgear needs to be evaluated. 10.11 Short-circuit rating 10.12 Electromagnetic compat	Heat dissipation capacity	P _{diss}	W	0
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.4.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3.0 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.1 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed.	EC/EN 61439 design verification			
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Dees not apply, since the entire switchgear needs to be evaluated. 10.4.1 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.1 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed.	10.2 Strength of materials and parts			
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.1 Power-frequency electric strength 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9 Temperature rise 10.9.1 Temperature rise 10.9.2 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed. In the device meets the requirements, provided the information in the instruction	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In panel builder's responsibility. In panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. It is the panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed. In the device meets the requirements, provided the information in the instruction.	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction				Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder is responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In panel builder's responsibility. In panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must observed. In the device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In panel builder is responsibility. The specifications for the switchgear must observed. In the panel builder's responsibility. The specifications for the switchgear must observed. In the device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. 1s the panel builder's responsibility. Is the panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed. The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed. The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must observed. Is the panel builder's responsibility. The specifications for the switchgear must observed. The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Short-circuit rations 10.15 the panel builder's responsibility. The specifications for the switchgear must observed. 10.15 The panel builder's responsibility. The specifications for the switchgear must observed. 10.16 Temperature rise 10.17 Short-circuit rating 10.18 The panel builder's responsibility. The specifications for the switchgear must observed. 10.19 The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9.1 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function Is the panel builder's responsibility. Is the panel builder is responsibility. The specifications for the switchgear must observed. The panel builder's responsibility. The specifications for the switchgear must observed. The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder is responsibility. The panel builder is responsibility is responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Steppend builder's responsibility. The specifications for the switchgear must observed. 10.15 The panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Steppend builder's responsibility. The specifications for the switchgear must observed. 10.15 The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder is responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
provide heat dissipation data for the devices. 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise			· · · · · · · · · · · · · · · · · · ·
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating			
	10.12 Electromagnetic compatibility			
	10.13 Mechanical function			

Technical data ETIM 5.0

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Auxiliary switch block (ecl@ss8-27-37-13-02 [AKN342009])

Number of contacts as change-over contact		0
Number of contacts as normally open contact		1
Number of contacts as normally closed contact		1
Rated operation current le at AC-15, 230 V	Α	3
Type of electric connection		Screw connection
Mounting method		Half-integrated