

MCB enclosure, +door, 3x9space units, HxWxD=375x250x150mm

Part no. Article no.

AE/I43E/T 002612




## **Delivery program**

Dimensions		mm			
Product range			Ci insulated enclosures		
Basic function			Prepared enclosures		
Product function			MCB individual enclosures		
Accessories			MCB individual enclosures		
Single unit/Complete unit			Stand-alone device		
Description			Metric cable entry knockouts in all sides For flush mounting devices with frame size 1 to DIN 43880 Transparent cover with quick-release fasteners Transparent door for operator access to devices fitted Mounting rails for snap-fitting the devices Blanking strip for unused mounting locations Protective shroud with inscription label PE/N screw terminals Fixing straps for wall fixing Sealable cover fasteners		
Degree of Protection			IP65		
Width		mm	250		
Height		mm	375		
Depth		mm	150		
1-pole MCBs		Number	27		
PE and N terminals, quantity x cross-section		mm <sup>2</sup>	On each: 4 x (6 - 35) On each: 20 x (1 - 4)		
Model					
Type Door			Transparent		
Notes C D	6	2 x M50/32 6 x M25/16 8 x M20 1 x M50/32 6 x M25/16			

## Design verification as per IEC/EN 61439

Technical data for design verification						
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890						
Individual enclosure for wall mounting	P <sub>V</sub>	CO	19			
Starting enclosure for wall mounting	P <sub>V</sub>	CO	17			
Middle enclosure for wall mounting	P <sub>V</sub>	CO	16			
Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees, calculated as per IEC 60890						

Individual enclosure for wall mounting	P <sub>V</sub>	CO	38
Starting enclosure for wall mounting	P <sub>V</sub>	CO	35
Middle enclosure for wall mounting	P <sub>V</sub>	CO	32
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Lower part: 960 °C / cover: 850 °C; meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Not relevant to indoor installations.
10.2.5 Lifting			10 kg per enclosure with support frame and lifting aid met; assembled and secured as per the latest applicable instruction leaflet.
10.2.6 Mechanical impact			IK10
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			IP65
10.4 Clearances and creepage distances			Is the panel builder's responsibility.
10.5 Protection against electric shock			Protection class 2, therefore not applicable.
10.6 Incorporation of switching devices and components			Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			U <sub>i</sub> = 1000 V AC
10.9.3 Impulse withstand voltage			8 kV
10.9.4 Testing of enclosures made of insulating material			Meets the product standard's requirements.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility.
10.13 Mechanical function			Meets the product standard's requirements.



## Additional product information (links)

Manufacturer's Declaration CI-RoHS Declaration of conformity ftp://ftp.moeller.net/DOCUMENTATION/PDF/2013-01-31\_Ci\_RoHS.pdf ftp://ftp.moeller.net/DOCUMENTATION/PDF/ci\_ce.pdf