





Similar to illustration

		Miniature circuit breakers
		2 pole
		C
		Switchgear for industrial and advanced commercial applications
In	А	20
	kA	25
		AZ
	I _n	"

Technical data

Electrical

Standards			IEC/EN 60947-2
Rated operational voltage	U _e	V	
	U _e	V AC	230/400
		V DC	60 (per pole)
Rated switching capacity acc. to IEC/EN 60947-2		kA	25
Operational switching capacity		kA	20
Characteristic			Similar: D, C
Max. back-up fuse		A gL/gG	200
Selectivity Class			Compliant with Class 3
Lifespan	Operations		> 10000
Direction of incoming supply			as required
Mechanical			
Standard front dimension		mm	45
Enclosure height		mm	90
Terminal protection			Finger and back-of-hand proof to BGV A2
Mounting width per pole		mm	27
Mounting			IEC/EN 60715 top-hat rail
Degree of Protection			IP20, IP40 (when fitted)
Terminals top and bottom			Lift terminals
Terminal capacities		mm ²	
		mm ²	2.5 50

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	А	20
Heat dissipation per pole, current-dependent	P _{vid}	W	0
Equipment heat dissipation, current-dependent	P _{vid}	W	5.42
Static heat dissipation, non-current-dependent	P _{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
			linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.

leets the product standard's requirements.
leets the product standard's requirements.
leets the product standard's requirements.
leets the product standard's requirements.
oes not apply, since the entire switchgear needs to be evaluated.
oes not apply, since the entire switchgear needs to be evaluated.
leets the product standard's requirements.
oes not apply, since the entire switchgear needs to be evaluated.
leets the product standard's requirements.
oes not apply, since the entire switchgear needs to be evaluated.
oes not apply, since the entire switchgear needs to be evaluated.
s the panel builder's responsibility.
s the panel builder's responsibility.
s the panel builder's responsibility.
s the panel builder's responsibility.
s the panel builder's responsibility.
he panel builder is responsible for the temperature rise calculation. Eaton will rovide heat dissipation data for the devices.
s the panel builder's responsibility. The specifications for the switchgear must be bserved.
the panel builder's responsibility. The specifications for the switchgear must be bserved.
he device meets the requirements, provided the information in the instruction aflet (IL) is observed.


Technical data ETIM 6.0


Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)


Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011])


Release characteristic		C
Number of poles (total)		2
Number of protected poles		1
Nominal rated current	А	20
Nominal rated voltage	V	400
Rated short-circuit breaking capacity Icn EN 60898 at 230 V	kA	25
Rated short-circuit breaking capacity Icn EN 60898 at 400 V	kA	25
Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V	kA	0
Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V	kA	0
Voltage type		AC
Current limiting class		3
Frequency	Hz	50 - 60
Concurrently switching N-neutral		No
Suitable for flush-mounted installation		No
Over voltage category		3
Pollution degree		2
Width in number of modular spacings		3
Built-in depth	mm	75
Additional equipment possible		Yes
Degree of protection (IP)		IP20















Dimensions



Additional product information (links)

AWA1220-1755 Circiut-breaker

AWA1220-1755 Circiut-breaker

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/17550701.pdf