

Floor standing distribution board, IVS, IP54, HxWxD=2060x830x320mm

Part no. Article no. BPM-F-830/20/3-P-IVS 111392



Delivery program

| Product range | | | Service distribution board IVS |
|--------------------------------------|---|----|--|
| Basic function | | | Floor-standing enclosures |
| Single unit/Complete unit | | | Complete housing |
| Degree of Protection | | | IP54 (only with door and flange) |
| Description | | | Profi Plus basic enclosures Monoblock enclosure with door and rotary lever Including open cable entries top and bottom, prepared for F3A flange Exchangeable door hinges Covered hinges Door opening angle 100° |
| Material | | | Sheet steel |
| Surface finish | | | Polyester powder coating Phosphated RAL 7035, light grey |
| Colour | | | light gray (RAL 7035) |
| Information about equipment supplied | | | Including mounting system for the IVS mounting units including insulating surround and mounted insulated support bracket |
| Width | r | mm | 830 |
| Height | I | mm | 2060 |
| Depth | r | mm | 320 |

Technical data

| General | | | |
|--|----------------|----|--|
| Standards | | | EN 60439-1/3 IEC 62208 |
| Protection class | | | 1 |
| Degree of Protection | | | IP54 (only with door and flange) |
| Power loss | | | |
| Max. admissible heat dissipation, ambient air temperature +35 $^{\circ}\mathrm{C}$ | | W | 391 |
| Weight | | kg | 71 |
| Material characteristics | | | |
| Material | | | Sheet steel |
| Surface treatment | | | Painting, phosphated and polyester powder coating |
| Surface finish | | | Polyester powder coating Phosphated RAL 7035, light grey |
| Colour | | | light gray (RAL 7035) |
| Material characteristics | | | |
| Type Door | | | Doors with covered hinges Can be removed from 90° |
| door opening angle | | | 100° (single mounting) |
| Door interlock | | | Hinge handle with roller lever lock Cylinder lock Double-ward lock |
| Material properties | | | |
| Mechanical | | | |
| Impact resistance | | | IK07 |
| Cable entry | | | Open cable entry, prepared for F3A flanges |
| Electrical | | | |
| Rated operational voltage | U _e | V | 690 |
| | | | |

| Rated frequency | f | Hz | 50 |
|--|----------------|----|--|
| Rated operational current | l _e | А | 630 |
| Max. admissible heat dissipation, ambient air temperature +35 $^{\circ}\mathrm{C}$ | | W | 391 |
| Earthings | | | M6 weld stud (base frame) M5 self-tapping screw (enclosure side plate, top/bottom panel) M6 weld stud (door) |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|----------------|----|--|
| Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890 | | | |
| Individual enclosure, free-standing | P _V | CO | 220 |
| Starting enclosure, free-standing | Pv | CO | 212 |
| Middle enclosure, free-standing | Pv | CO | 205 |
| · · · · | - | | |
| Individual enclosure for wall mounting | Pv | C0 | 200 |
| Starting enclosure for wall mounting | P _V | CO | 195 |
| Middle enclosure for wall mounting | P _V | CO | 195 |
| Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees, calculated as per IEC 60890 | | | |
| Individual enclosure, free-standing | PV | CO | 442 |
| Starting enclosure, free-standing | P _V | C0 | 426 |
| Middle enclosure, free-standing | P _V | CO | 412 |
| Individual enclosure for wall mounting | P _V | C0 | 400 |
| Starting enclosure for wall mounting | P _V | CO | 391 |
| Middle enclosure for wall mounting | P _V | C0 | 391 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Not relevant to indoor installations. |
| 10.2.5 Lifting | | | Met; assembled and secured as per the latest applicable instruction leaflet. |
| 10.2.6 Mechanical impact | | | IK07 |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | IP54 |
| 10.4 Clearances and creepage distances | | | Is the panel builder's responsibility. |
| 10.5 Protection against electric shock | | | $<$ 0.1 $\Omega;$ meets the product standard's requirements. |
| 10.6 Incorporation of switching devices and components | | | Is the panel builder's responsibility. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | U _i = 440 V AC |
| 10.9.3 Impulse withstand voltage | | | 4 kV |
| 10.9.4 Testing of enclosures made of insulating material | | | Does not apply to metal enclosures. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. |
| 10.13 Mechanical function | | | Meets the product standard's requirements. |