

Floor standing distribution board

Part no. Article no. BPM-F-850/20/2-P-EP 142446



## Design verification as per IEC/EN 61439

| Technical data for design verification   |                |    |  |
|--|----------------|----|--|
| Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890                  |                |    |  |
| Individual enclosure, free-standing  | P <sub>V</sub> | C0 | 202  |
| Starting enclosure, free-standing  | PV             | C0 | 197  |
| Middle enclosure, free-standing  | Pv             | C0 | 193  |
| Individual enclosure for wall mounting   | P <sub>V</sub> | C0 | 183  |
| Starting enclosure for wall mounting   | P <sub>V</sub> | C0 | 188  |
| Middle enclosure for wall mounting   | P <sub>V</sub> | C0 | 172  |
| Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees, calculated as per IEC 60890                  |                |    |  |
| Individual enclosure, free-standing  | PV             | C0 | 406  |
| Starting enclosure, free-standing  | P <sub>V</sub> | CO | 396  |
| Middle enclosure, free-standing  | P <sub>V</sub> | CO | 387  |
| Individual enclosure for wall mounting   | P <sub>V</sub> | C0 | 368  |
| Starting enclosure for wall mounting   | Pv             | C0 | 376  |
| Middle enclosure for wall mounting   | P <sub>V</sub> | C0 | 346  |
| IEC/EN 61439 design verification   |                |    |  |
| 10.2 Strength of materials and parts   |                |    |  |
| 10.2.2 Corrosion resistance  |                |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                |    | Not relevant to indoor installations.  |
| 10.2.5 Lifting   |                |    | Met; assembled and secured as per the latest applicable instruction leaflet.   |
| 10.2.6 Mechanical impact   |                |    | IK07   |
| 10.2.7 Inscriptions  |                |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                |    | IP54   |
| 10.4 Clearances and creepage distances   |                |    | Is the panel builder's responsibility.   |
| 10.5 Protection against electric shock   |                |    | $<$ 0.1 $\Omega;$ meets the product standard's requirements.   |
| 10.6 Incorporation of switching devices and components   |                |    | Is the panel builder's responsibility.   |
| 10.7 Internal electrical circuits and connections  |                |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                |    |  |
| 10.9.2 Power-frequency electric strength   |                |    | U <sub>i</sub> = 440 V AC  |
| 10.9.3 Impulse withstand voltage   |                |    | 8 kV   |
| 10.9.4 Testing of enclosures made of insulating material   |                |    | Does not apply to metal enclosures.  |
| 10.10 Temperature rise   |                |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                |    | Is the panel builder's responsibility.   |
| 10.12 Electromagnetic compatibility  |                |    | Is the panel builder's responsibility.   |
| 10.13 Mechanical function  |                |    | Meets the product standard's requirements.   |

## **Technical data ETIM 6.0**

Cabinet enclosures (EG000011) / Enclosure/switchgear cabinet (empty) (EC000261)

| Electric engineering, automation, process control engineering / Electrical cabinet, | housing, rack / Ele | ectrical | cabinet (empty) / Electrical cabinet (ecl@ss8.1-27-18-01-01 [AGZ056013]) |
|---|---------------------|----------|--|
| Width   | m                   | ım       | 850  |
| Height  | m                   | ım       | 2060   |
| Depth   | m                   | ım       | 250  |
| Material  |                     |          | Steel  |
| Type of surface   |                     |          | With powder coating  |
| Colour  |                     |          | Grey   |
| RAL-number  |                     |          | 7035   |
| With mounting plate   |                     |          | No   |
| Mounting plate depth-adjustable   |                     |          | No   |
| Number of locks   |                     |          | 0  |
| Floor installation possible   |                     |          | Yes  |
| Wall fastening possible   |                     |          | No   |
| Wall build in   |                     |          | No   |
| Pole fastening  |                     |          | No   |
| Tackable  |                     |          | Yes  |
| Number of doors   |                     |          | 1  |
| Suitable for metrical mounting  |                     |          | No   |
| Suitable for outdoor set-up   |                     |          | No   |
| Pitched roof  |                     |          | No   |
| EMC-version   |                     |          | No   |
| Impact strength   |                     |          | IK07   |
| Degree of protection (IP)   |                     |          | IP54   |
| With glazed door  |                     |          | No   |
| With ventilation door   |                     |          | No   |
| With backside door  |                     |          | No   |