

Auxiliary contact, 1N/O+1N/C, side exterior, screw connection

Powering Business Worldwide*

Part no. DILP800-XHI-SA
Article no. 207471
Catalog No. XTCFAXSCN11

Delivery program

Product range			Accessories
Accessories			Auxiliary contact modules
Function			for standard applications
Connection technique			Spring-loaded terminals
Rated operational current			
AC-15			
220 V 230 V 240 V	I _e	Α	4
380 V 400 V 415 V	l _e	Α	4
Contacts			
N/O = Normally open			1 N/0
N/C = Normally closed			1 NC
Mounting type			Side mounted
Contact sequence			53 • †8 61 • ZZ

Technical data

Electrical specifications for standard auxiliary contacts

Interlocked opposing contacts within an auxiliary contact module (to IEC 60947-5-1 Annex L) $$			-
N/C contact (not late-break contact) suitable as a mirror contact (to IEC/EN 60947-4-1 Annex F)			DILP250 - DILP800
Rated impulse withstand voltage	U_{imp}	kV	6
Overvoltage category/pollution degree			III/3
Rated insulation voltage	Ui	V AC	690
Rated operational voltage	U _e	V AC	690
Safe isolation to EN 61140			
between coil and auxiliary contacts		V AC	1000
between the auxiliary contacts		V AC	400
Rated operational current		Α	
AC-15			
220 V 230 V 240 V	l _e	Α	4
380 V 400 V 415 V	le	Α	4
500 V	l _e	Α	1
Component lifespan			
at U _e = 230 V, AC-15, 3 A	Operations	x 10 ⁶	0.5
Short-circuit rating without welding			
max. fuse		A gG/gL	10

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	А	6
Heat dissipation per pole, current-dependent	P_{vid}	W	0.2
Equipment heat dissipation, current-dependent	P_{vid}	W	0
Static heat dissipation, non-current-dependent	P_{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0

Operating ambient temperature min.	°C	-40
Operating ambient temperature max.	°C	70
C/EN 61439 design verification		
10.2 Strength of materials and parts		
10.2.2 Corrosion resistance		Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures		Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat		Meets the product standard's requirements.
$10.2.3.3\mbox{Verification}$ of resistance of insulating materials to abnormal heat and fire due to internal electric effects		Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation		Meets the product standard's requirements.
10.2.5 Lifting		Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact		Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions		Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES		Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances		Meets the product standard's requirements.
10.5 Protection against electric shock		Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components		Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections		Is the panel builder's responsibility.
10.8 Connections for external conductors		Is the panel builder's responsibility.
10.9 Insulation properties		
10.9.2 Power-frequency electric strength		Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage		Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material		Is the panel builder's responsibility.
10.10 Temperature rise		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function		The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Auxiliary switch block (ecl@ss8.1-27-37-13-02 [AKN342010])

(consistent 2. or in all plants in any		
Number of contacts as change-over contact		0
Number of contacts as normally open contact		1
Number of contacts as normally closed contact		1
Rated operation current le at AC-15, 230 V	Α	6
Type of electric connection		Screw connection
Model		Top mounting
Mounting method		Side mounting

Additional product information (links)

IL03407025Z (AWA2100-1709) Auxiliary contacts

Switchgear of Power Factor Correction

IL03407025Z (AWA2100-1709) Auxiliary contacts ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL03407025Z2010_10.pdf

http://www.moeller.net/binary/ver_techpapers/ver934en.pdf Systems X-Start - Modern Switching Installations http://www.moeller.net/binary/ver_techpapers/ver938en.pdf Efficiently Fitted and Wired Securely

Mirror Contacts for Highly-Reliable Information http://www.moeller.net/binary/ver_techpapers/ver944en.pdf Relating to Safety-Related Control Functions

Effect of the Cabel Capacitance of Long Control http://www.moeller.net/binary/ver_techpapers/ver949en.pdf

Cables on the Actuation of Contactors Motor starters and "Special Purpose Ratings" http://www.moeller.net/binary/ver_techpapers/ver953en.pdf

for the North American market Switchgear for Luminaires http://www.moeller.net/binary/ver_techpapers/ver955en.pdf

Standard Compliant and Functionally Safe http://www.moeller.net/binary/ver_techpapers/ver956en.pdf Engineering Design with Mechanical Auxiliary Contacts

The Interaction of Contactors with PLCs	http://www.moeller.net/binary/ver_techpapers/ver957en.pdf
Busbar Component Adapters for modern Industrial control panels	http://www.moeller.net/binary/ver_techpapers/ver960en.pdf