

Proximity switch, inductive, 1N/0, Sn=5mm, 3L, 10-30VDC, NPN, M18, insulated material, line 2m



Part no. E55CAL18T110 Article no. 135824 Catalog No. E55CAL18T110

	-		
110	III/OFI	n ro	~ ~ ~
	livery		11211
		DIO	

Basic function			Inductive Sensors
Product range			E55 Limit Switch Style Series
Connection			3-wire
Design (outer dimensions)		mm	M18 x 1
Rated operational voltage	U _e		10 - 30 V DC
Rated switching distance	S_n	mm	5
Type of mounting			Flush
Switching type			NPN
For connection of:			2 m connection cable
Contacts			
N/0 = Normally open			1 N/O
Material			Insulated material
Degree of Protection			IP66

Technical data

General

Standards		IEC/EN 60947-5-2
Ambient temperature		-25 - +70
Mechanical shock resistance		30 Shock duration 11 ms
Degree of Protection		IP66

Characteristics

Characteristics			
Rated switching distance			
Rated switching distance	S_n	mm	5
Repetition accuracy of S _n		%	10
Temperature drift of S _n		%	10
Switching hysteresis of S_n		%	20
Rated operational voltage	U _e		10 - 30 V DC
Supply frequency			50 - 60
Residual ripple of U_e		%	10
Maximum load current	l _e	mA	< 200
Operating current in the switched state at 24 V DC	Ib	mA	3
Voltage drop at I_e	U_{d}	V	8
Switching Frequency		Hz	1000
Switching state display		LED	Red
Protective functions			Short-circuit protective device Protection against polarity reversal
Connection			3-wire
Contacts			
N/O = Normally open			1 N/O
Style			
Design (outer dimensions)		mm	M18 x 1
For connection of:			2 m connection cable
Material			Insulated material

Design verification as per IEC/EN 61439


•		
Technical data for design verification		
Operating ambient temperature min.	°C	-25

Operating ambient temperature max. °C 70

Approvals

• •	
Product Standards	CE marking
Max. Voltage Rating	30 V DC
Degree of Protection	IEC: IP66; UL/CSA: NEMA 4, 4X, 13

Dimensions



Additional product information (links)

IL05301005Z E55 Series Barrel-Style Inductive Sensors

Sensors

IL05301005Z E55 Series Barrel-Style Inductive ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL05301005Z2016_07.pdf