





Similar to illustration

| Delivery program   |                   |    |  |
|--|-------------------|----|--|
| Basic function   |                   |    | Miniature circuit breakers   |
| Number of poles  |                   |    | 3 pole+N   |
| Tripping characteristic  |                   |    | D  |
| Application  |                   |    | Switchgear for industrial and advanced commercial applications   |
| Rated current  | l <sub>n</sub>    | A  | 1.5  |
| Rated switching capacity acc. to IEC/EN 60947-2  |                   | kA | 15   |
| Product range  |                   |    | FAZ  |
|  |                   |    |  |
| Technical data<br>Electrical   |                   |    |  |
| Rated switching capacity acc. to IEC/EN 60947-2  |                   | kA | 15   |
| Design verification as per IEC/EN 61439  |                   |    |  |
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | А  | 1.5  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 3.6  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -40  |
| Operating ambient temperature max.   |                   | °C | 75   |
|  |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity  |
| IEC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must b<br>observed.                                 |

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 6.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011]) |    |         |  |  |
|--|----|---------|--|--|
| Release characteristic   |    | D       |  |  |
| Number of poles (total)  |    | 4       |  |  |
| Number of protected poles  |    | 4       |  |  |
| Nominal rated current  | А  | 1.5     |  |  |
| Nominal rated voltage  | V  | 400     |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  | kA | 10      |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  | kA | 10      |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V   | kA | 15      |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   | kA | 15      |  |  |
| Voltage type   |    | AC      |  |  |
| Current limiting class   |    | 3       |  |  |
| Frequency  | Hz | 50 - 60 |  |  |
| Concurrently switching N-neutral   |    | Yes     |  |  |
| Suitable for flush-mounted installation  |    | No      |  |  |
| Over voltage category  |    | 3       |  |  |
| Pollution degree   |    | 2       |  |  |
| Width in number of modular spacings  |    | 4       |  |  |
| Built-in depth   | mm | 70.5    |  |  |
| Additional equipment possible  |    | Yes     |  |  |
| Degree of protection (IP)  |    | IP20    |  |  |