

Part no. Article no. Catalog No. FAZT-D40/1N 142516 FAZT-D40/1N



Similar to illustration

| Basic function  |                   |    | Miniature circuit breakers  |
|---|-------------------|----|---|
| Number of poles   |                   |    | 1 pole+N  |
| Tripping characteristic   |                   |    | D   |
| Application   |                   |    | Switchgear for industrial and advanced commercial applications              |
| Rated current   | I <sub>n</sub>    | Α  | 40  |
| Rated switching capacity acc. to IEC/EN 60947-2   |                   | kA | 15  |
| Product range   |                   |    | FAZ-T   |
| Fechnical data  |                   |    |   |
| Electrical  |                   |    |   |
| Rated switching capacity acc. to IEC/EN 60947-2   |                   | kA | 15  |
| Design verification as per IEC/EN 61439   |                   |    |   |
| Fechnical data for design verification  |                   |    |   |
| Rated operational current for specified heat dissipation  | I <sub>n</sub>    | A  | 40  |
| Heat dissipation per pole, current-dependent  | P <sub>vid</sub>  | W  | 0   |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub>  | w  | 3.8   |
|   |                   |    |   |
| Static heat dissipation, non-current-dependent  | P <sub>vs</sub>   | W  | 0   |
| Heat dissipation capacity   | P <sub>diss</sub> | W  | 0   |
| Operating ambient temperature min.  |                   | °C | -40   |
| Operating ambient temperature max.  |                   | °C | 75  |
|   |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity |
| IEC/EN 61439 design verification  |                   |    |   |
| 10.2 Strength of materials and parts  |                   |    |   |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.                                  |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat<br>and fire due to internal electric effects |                   |    | Meets the product standard's requirements.                                  |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Meets the product standard's requirements.                                  |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.                                  |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.                                  |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.          |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.                                      |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.                                      |
| 10.9 Insulation properties  |                   |    |   |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.                                      |
| 10.0.2 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.                                      |
| 10.9.3 Impulse withstand voltage  |                   |    |   |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.                                      |

| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

## **Technical data ETIM 6.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

| Electric engineering, automation, process control engineering / Electrical installation [AAB905011]) | n, device / Miniature ci | rcuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 |
|--|--------------------------|---|
| Release characteristic   |                          | D   |
| Number of poles (total)  |                          | 2   |
| Number of protected poles  |                          | 2   |
| Nominal rated current  | А                        | 40  |
| Nominal rated voltage  | V                        | 230   |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  | kA                       | 15  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  | kA                       | 15  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V                                       | kA                       | 15  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V                                       | kA                       | 15  |
| Voltage type   |                          | AC  |
| Current limiting class   |                          | 3   |
| Frequency  | Hz                       | 50 - 60   |
| Concurrently switching N-neutral   |                          | Yes   |
| Suitable for flush-mounted installation  |                          | No  |
| Over voltage category  |                          | 3   |
| Pollution degree   |                          | 2   |
| Width in number of modular spacings  |                          | 1.5   |
| Built-in depth   | mm                       | 70.5  |
| Additional equipment possible  |                          | Yes   |
| Degree of protection (IP)  |                          | IP20  |