

### Actuating roller lever

Part no. HR518 Article no. 048106 Catalog No. HR518



# **Delivery program**

| Basic function       |   |    | Components   |
|----------------------|---|----|--|
| Part group reference |   |    | AT4  |
| Product range        |   |    | Actuators  |
| Function             |   |    | actuating roller lever   |
| Diameter             | Ø | mm | 50   |
| Description          |   |    | For adding R-AT4 rotary drive<br>With roller from insulated material |
| Lever length         | I | mm | 50   |
| For use with         |   |    | R-AT4  |

## **Technical data**

#### General

| Standards             |                 | IEC/EN 60947   |
|-----------------------|-----------------|--|
| Climatic proofing     |                 | Damp heat, constant, to IEC 60068-2-78; damp heat, cyclical, to IEC 60068-2-30 |
| Mounting position     |                 | As required  |
| Terminal capacities   | mm <sup>2</sup> |  |
| Solid                 | mm <sup>2</sup> | 1 x (0.75 - 2.5)<br>2 x (0.75 - 1.5)   |
| Flexible with ferrule | $mm^2$          | 1 x (0.5 - 1.5)<br>2 x (0.5 - 1.5)   |

#### **Contacts/switching capacity**

| Rated impulse withstand voltage          | $U_{imp}$      | V AC    | 6000     |
|--|----------------|---------|----------|
| Rated insulation voltage                 | Ui             | V       | 500      |
| Overvoltage category/pollution degree    |                |         | III/3    |
| Rated operational current                | I <sub>e</sub> | Α       |          |
| AC-15                                    |                |         |          |
| 24 V                                     | I <sub>e</sub> | Α       | 10       |
| 220 V 230 V 240 V                        | I <sub>e</sub> | Α       | 6        |
| 380 V 400 V 415 V                        | I <sub>e</sub> | Α       | 4        |
| DC-13                                    |                |         |          |
| 24 V                                     | I <sub>e</sub> | Α       | 3        |
| 110 V                                    | I <sub>e</sub> | Α       | 0.8      |
| 220 V                                    | I <sub>e</sub> | Α       | 0.4      |
| Supply frequency                         |                | Hz      | max. 400 |
| Short-circuit rating to IEC/EN 60947-5-1 |                |         |          |
| max. fuse                                |                | A gG/gL | 6        |
| Repetition accuracy                      |                | mm      | 0.02     |

#### Mechanical variables

| Mechanical variables                                       |              |    |                   |
|--|--------------|----|-------------------|
| Contact temperature of roller head                         |              | °C | ≦ <sub>100</sub>  |
| Mechanical shock resistance (half-sinusoidal shock, 20 ms) |              |    |                   |
| Standard-action contact                                    |              | g  | 5                 |
| Snap-action contact  |              | g  | 2                 |
| Operating frequency  | Operations/h |    | ≦ <sub>6000</sub> |

#### Actuation

| Mechanical                        |    |     |
|-----------------------------------|----|-----|
| Actuating torque of rotary drives | Nm | 0.3 |

| Design verification as per IEC/EN 61439  |                   |    |  |  |
|--|-------------------|----|--|--|
| Technical data for design verification   |                   |    |  |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 0  |  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 0  |  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |  |
| Operating ambient temperature min.   |                   | °C | -25  |  |
| Operating ambient temperature max.   |                   | °C | 70   |  |
| IEC/EN 61439 design verification   |                   |    |  |  |
| 10.2 Strength of materials and parts   |                   |    |  |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |  |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |  |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |  |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $\frac{1}{2} = \frac{1}{2} \left( \frac{1}{2} + \frac{1}{2} \right) \left( \frac{1}{2} + \frac{1}{2} + \frac{1}{2} \right) \left( \frac{1}{2} + \frac{1}$ |                   |    | Meets the product standard's requirements.   |  |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Please enquire   |  |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |  |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |  |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |  |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |  |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |  |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |  |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |  |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |  |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |  |
| 10.9 Insulation properties   |                   |    |  |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |  |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |  |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |  |
| 10.10 Temperature rise   |                   |    | Not applicable.  |  |
| 10.11 Short-circuit rating   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                             |  |
| 10.12 Electromagnetic compatibility  |                   |    | Is the panel builder's responsibility. The specifications for the switch<br>gear must be observed. $\label{eq:constraint}$ |  |
| 10.13 Mechanical function  |                   |    | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                   |  |

### **Technical data ETIM 6.0**

Sensors (EG000026) / Drive head for position switches/hinge switches (EC001483)

Electric engineering, automation, process control engineering / Binary sensor technology, safety-related sensor technology / Position switch / Drive head for position switches (ecl@ss8.1-27-27-06-04 [BAA083009])

| Type of control element | Rotary lever |  |
|-------------------------|--------------|--|

## **Dimensions**

