

Panel enclosure, with gland plate and cable glands, HxWxD=375x250x225mm



Part no. KST34-200 079266 Article no.

Delivery program

Delivery program		
Product range		Ci insulated enclosures
Basic function		Basic enclosures
Product function		Panel enclosure with gland plates fitted
Single unit/Complete unit		Stand-alone device
Degree of Protection		IP65
Description		Sealable cover fasteners Sides closed, but with full area knockout Open top Fitting of cable supports in the distribution board with wedge-lock fastener Gland plate can be split, cables can be inserted from the front
Model base		Plain
Type cover		Transparent
Width	mm	250
Height	mm	375
Depth	mm	225
Mounting depth with mounting plate	mm	200
Mounting depth for mounting rail 7.5 mm height	mm	192.5
Mounting depth for mounting rail 15 mm height	mm	185
Dimensions	mm	250
Enclosure depth		
Legend for the graphic		Dimensions from top: Mounting depth with mounting plate Mounting depth for mounting rail 7.5 mm height Mounting depth for mounting rail 15 mm height Enclosure depth
Enclosure depth Cable entry	mm	225 2 x 14 - 54
Cable Gill y		∠∧ IT - JT

Distribution board with/without gland plates fitted

• Cover transparent, cover fasteners can be sealed

Ci distribution board enclosure without cable gland plates

- Degree of protection IP65
 Sides closed, but with full area knockout, open top and bottom

KST distribution board enclosure with cable gland plates fitted

- Degree of protection IP65 from below
- Sides closed, but with full area knockout, open at top
 Fitting of cable supports in the distribution board with wedge-lock fastner
- Gland plate can be split, cables can be inserted from the front

Technical data

General


General		
Ambient temperature	°C	-40 - +80
Ambient temperature		
Mean value over 24 hours	°C	35
Limit values	°C	
Ambient temperature limit value min.	°C	-5
Ambient air temperature, limit values max.	°C	40
Degree of Protection		IP65
Protection type		IP65 (Enclosure) IP65 (KST cable entries from below) IP64 (KST cable entries from above) IP00 (Cable entry open)
Components		Switchgear assembly components are type-tested. They are available individually for the self-assembly of switchgear installations, distribution boards and control panels.
Devices that can be fitted		The reference values indicated in the table apply to the basic elements of the distribution board. As far as devices, terminals etc. fitted into the enclosures are concerned, their own specific technical data and rated values apply.
Standards		
TTA - Type Tested Assemblies		IEC/EN 60439-1, VDE 0660 Part 500
Low-voltage fuses		IEC/EN 60269, VDE 0636
Type test		VDE 0660 Part 500, IEC/EN 60439-1
Creepage and clearance distances		III/3 to IEC/EN 60439-1
Flammability characteristics - Glow rod test		VDE 0304 Part 3 level IIb, level IIb to IEC 60707
Regulation for the fire resistance tests of electrical products, their modules and components, glow wire test		VDE 0471 Part 2
Operating and ambient conditions to VDE 0660 Part 500		
Ambient temperature		
Mean value over 24 hours	°C	35
Limit values	°C	-5 40
Indoor installation		
Relative humidity		90 % (at 20°C) 50% (at 40°C)
Altitude	m	Max. 2000
Protection type		IP65 (Enclosure) IP65 (KST cable entries from below) IP64 (KST cable entries from above) IP00 (Cable entry open)
Mounting grid	mm	25 (DIN 43660)
Colour		DAL 7022 makkla svav
Base		RAL 7032, pebble grey
Housing body		Transparent, colourless or RAL 7032, pebble grey
Surface finish		CINA: Transparent cover, opaque Galvanized
		Passivated
Material characteristics		Calvasized
Surface finish		Galvanized Passivated
Colour		
Base		RAL 7032, pebble grey
Housing body		Transparent, colourless or RAL 7032, pebble grey

Design verification as per IEC/EN 61439

Technical data for design verification		
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890		

Individual enclosure for wall mounting	P_{V}	CO	23
Starting enclosure for wall mounting	P_{V}	CO	21
Middle enclosure for wall mounting	P_{V}	CO	19
Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees, calculated as per IEC 60890			
Individual enclosure for wall mounting	P_{V}	CO	47
Starting enclosure for wall mounting	P_{V}	CO	43
Middle enclosure for wall mounting	P_{V}	CO	39
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $\frac{1}{2} = \frac{1}{2} \left(\frac{1}{2} + \frac{1}{2} \right) \left(\frac{1}{2} + \frac{1}{2} + \frac{1}{2} \right) \left(\frac{1}{2} + \frac{1}$			Lower part: 960 °C / cover: 850 °C; meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Not relevant to indoor installations.
10.2.5 Lifting			10 kg per enclosure with support frame and lifting aid met; assembled and secured as per the latest applicable instruction leaflet.
10.2.6 Mechanical impact			IK10
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			IP65
10.4 Clearances and creepage distances			Is the panel builder's responsibility.
10.5 Protection against electric shock			Protection class 2, therefore not applicable.
10.6 Incorporation of switching devices and components			Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			U _i = 1000 V AC
10.9.3 Impulse withstand voltage			8 kV
10.9.4 Testing of enclosures made of insulating material			Meets the product standard's requirements.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility.
10.13 Mechanical function			Meets the product standard's requirements.

Dimensions



Additional product information (links)

AWA3200-0572 Gland plates	
AWA3200-0572 Gland plates	ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/05720588.pdf
Manufacturer's Declaration CI-RoHS	ftp://ftp.moeller.net/DOCUMENTATION/PDF/2013-01-31_Ci_RoHS.pdf
Declaration of conformity	ftp://ftp.moeller.net/DOCUMENTATION/PDF/ci_ce.pdf