

Panel enclosure, with gland plate and cable glands, HxWxD=375x375x150mm



Part no. KST44-125 Article no. 088758

Delivery program

Delivery program		
Product range	Ci insula	ated enclosures
Basic function	Basic e	nclosures
Product function	Panel e	nclosure with gland plates fitted
Single unit/Complete unit	Stand-a	lone device
Degree of Protection	IP65	
Description	Sides cl Open to Fitting o	e cover fasteners osed, but with full area knockout p f cable supports in the distribution board with wedge-lock fastener late can be split, cables can be inserted from the front
Model base	Plain	
Type cover	Transpa	rent
Width	mm 375	
Height	mm 375	
Depth	mm 150	
Mounting depth with mounting plate	mm 125	
Mounting depth for mounting rail 7.5 mm height	mm 117.5	
Mounting depth for mounting rail 15 mm height	mm 110	
Dimensions	mm S	56 44-
Enclosure depth		
Legend for the graphic	Mountir Mountir Mountir	ons from top: 1g depth with mounting plate 1g depth for mounting rail 7.5 mm height 1g depth for mounting rail 15 mm height re depth
Enclosure depth Cable cate	mm	125 117.5 110
Cable entry	3 x 14 - 0	В

Notes

Distribution board with/without gland plates fitted

• Cover transparent, cover fasteners can be sealed

Ci distribution board enclosure without cable gland plates

- Degree of protection IP65
 Sides closed, but with full area knockout, open top and bottom

KST distribution board enclosure with cable gland plates fitted

- Degree of protection IP65 from below
- Sides closed, but with full area knockout, open at top
 Fitting of cable supports in the distribution board with wedge-lock fastner
 Gland plate can be split, cables can be inserted from the front

Technical data

General

Housing body		Transparent, colourless or RAL 7032, pebble grey
Base		RAL 7032, pebble grey
Colour		
Surface finish		Galvanized Passivated
Material characteristics		
Surface finish		CINA: Transparent cover, opaque Galvanized Passivated
Housing body		
Base Housing body		RAL 7032, pebble grey Transparent, colourless or RAL 7032, pebble grey
Colour		PAI 7022 pabble gray
Mounting grid	mm	25 (DIN 43660)
Mounting grid		IP65 (KST cable entries from below) IP64 (KST cable entries from above) IP00 (Cable entry open)
Protection type		IP65 (Enclosure)
Altitude	m	Max. 2000
Relative humidity		90 % (at 20°C) 50% (at 40°C)
Indoor installation	Ť	
Limit values	°C	-5 40
Mean value over 24 hours	°C	35
Ambient temperature		
and components, glow wire test Operating and ambient conditions to VDE 0660 Part 500		
Regulation for the fire resistance tests of electrical products, their modules		VDE 0471 Part 2
Flammability characteristics - Glow rod test		VDE 0304 Part 3 level IIb, level IIb to IEC 60707
Creepage and clearance distances		III/3 to IEC/EN 60439-1
Type test		VDE 0660 Part 500, IEC/EN 60439-1
Low-voltage fuses		IEC/EN 60433-1, VDE 0606 Part 300
Standards TTA - Type Tested Assemblies		IEC/EN 60439-1, VDE 0660 Part 500
Devices that can be fitted		The reference values indicated in the table apply to the basic elements of the distribution board. As far as devices, terminals etc. fitted into the enclosures are concerned, their own specific technical data and rated values apply.
Components		Switchgear assembly components are type-tested. They are available individually for the self-assembly of switchgear installations, distribution boards and control panels.
Protection type		IP65 (Enclosure) IP65 (KST cable entries from below) IP64 (KST cable entries from above) IP00 (Cable entry open)
Degree of Protection		IP65
Ambient air temperature, limit values max.	°C	40
Ambient temperature limit value min.	°C	-5
Limit values	°C	
Mean value over 24 hours	°C	35
Ambient temperature		
Ambient temperature	°C	-40 - +80
General		

Technical data for design verification			
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees, calculated as per IEC 60890			
Individual enclosure for wall mounting	P_{V}	CO	25
Starting enclosure for wall mounting	P_V	CO	24
Middle enclosure for wall mounting	P_V	CO	23
Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees, calculated as per IEC 60890			
Individual enclosure for wall mounting	P_{V}	CO	51
Starting enclosure for wall mounting	P_{V}	CO	48
Middle enclosure for wall mounting	P_V	CO	45
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.		
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$			Lower part: 960 °C / cover: 850 °C; meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Not relevant to indoor installations.
10.2.5 Lifting	20 kg per enclosure with support frame and lifting aid met; assembled and secured as per the latest applicable instruction leaflet.		
10.2.6 Mechanical impact			IK10
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			IP65
10.4 Clearances and creepage distances			Is the panel builder's responsibility.
10.5 Protection against electric shock			Protection class 2, therefore not applicable.
10.6 Incorporation of switching devices and components			Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			U _i = 1000 V AC
10.9.3 Impulse withstand voltage			8 kV
10.9.4 Testing of enclosures made of insulating material			Meets the product standard's requirements.

10.10 Temperature rise

10.11 Short-circuit rating

10.13 Mechanical function

10.12 Electromagnetic compatibility


The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

Is the panel builder's responsibility.

Is the panel builder's responsibility.

Meets the product standard's requirements.

Dimensions



Additional product information (links)

AWA3200-0572 Gland plates	
AWA3200-0572 Gland plates	ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/05720588.pdf
Manufacturer's Declaration CI-RoHS	ftp://ftp.moeller.net/DOCUMENTATION/PDF/2013-01-31_Ci_RoHS.pdf
Declaration of conformity	ftp://ftp.moeller.net/DOCUMENTATION/PDF/ci_ce.pdf