

Pushbutton, flush, green, maintained

Powering Business Worldwide*

Part no. M22S-DR-G Article no. 216620 Catalog No. M22S-DR-GQ

Delivery program

Product range Basic function	RMQ-Titan
Rasic function	B. 11
Busic fullction	Pushbutton actuators
Single unit/Complete unit	Single unit
Design	Flat
	maintained
Button plate	
button plate	green
Button plate	
	Blank
Degree of Protection	IP67, IP69K
Front ring	Bezel: black
Connection to SmartWire-DT	Yes, with SWD-RMQ connections
Actuator travel and actuation force as per DIN EN 60947-5-1, K.5.4.1	
Minimum force for positive opening N	0
Front dimensions	22 x 22
Instructions	Stay-put/spring-return function can be changed on device

Technical data

General

delicitat			
Standards			IEC/EN 60947 VDE 0660
Lifespan, mechanical	Operations	x 10 ⁶	>1
Operating frequency	Operations/h		≦ ₁₈₀₀
Actuating force		n	\leq_5
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature			
Open		°C	-25 - +70
Storage		°C	- 40 - + 80
Mounting position			As required
Mechanical shock resistance		g	30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27

Design verification as per IEC/EN 61439

Technical data for design verification Rated operational current for specified heat dissipation In A 0 Heat dissipation per pole, current-dependent P _{vid} W 0 Equipment heat dissipation, current-dependent P _{vid} W 0 Static heat dissipation, non-current-dependent P _{vs} W 0 Heat dissipation capacity P _{diss} W 0 Operating ambient temperature min. °C -25	3			
Heat dissipation per pole, current-dependent P _{vid} W 0 Equipment heat dissipation, current-dependent P _{vid} W 0 Static heat dissipation, non-current-dependent P _{vs} W 0 Heat dissipation capacity P _{diss} W 0 Operating ambient temperature min.	Fechnical data for design verification			
Equipment heat dissipation, current-dependent P_{vid} W 0 Static heat dissipation, non-current-dependent P_{vs} W 0 Heat dissipation capacity P_{diss} W 0 Operating ambient temperature min. C C C C C	Rated operational current for specified heat dissipation	In	Α	0
Static heat dissipation, non-current-dependent P_{vs} W 0 Heat dissipation capacity P_{diss} W 0 Operating ambient temperature min. $^{\circ}$ $^{\circ}$ $^{\circ}$ $^{\circ}$ $^{\circ}$ $^{\circ}$ $^{\circ}$ $^{\circ}$ $^{\circ}$	Heat dissipation per pole, current-dependent	P _{vid}	W	0
Heat dissipation capacity P _{diss} W Operating ambient temperature min. W C -25	Equipment heat dissipation, current-dependent	P _{vid}	W	0
Operating ambient temperature min. °C -25	Static heat dissipation, non-current-dependent	P_{vs}	W	0
	Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature may	Operating ambient temperature min.		°C	-25
operating uniform temperature max.	Operating ambient temperature max.		°C	70

IEC/EN 61439 design verification	
10.2 Strength of materials and parts	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	Not applicable.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Front element for push button (EC000221)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for push-button actuators (ecl@ss8.1-27-37-12-10 [AKF028011])


1			
Colour button			Green
Number of command positions			1
Construction type lens			Round
Hole diameter	m	nm	22
Width opening	m	nm	0
Height meter opening	m	nm	0
Degree of protection (IP), front side			IP67
Type of button			Flat
Suitable for illumination			No
With protection cover			No
Labelled			No
Switching function latching			Yes
Spring-return			Yes
With front ring			Yes
Material front ring			Plastic
Colour front ring			Black


Approvals

Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	012528
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified

Dimensions







Additional product information (links)

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan System

 $ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716002Z2016_09.pdf$