

Main switch assembly kit, +additional handle red, size 1, NA type

Powering Business Worldwide

Part no. NZM1-XHB-DAR-NA Article no. 125959

Similar to illustration

| Del | livery | , nro | gram |
|-----|--------|-------|-------|
| שט | IIVEI | / piu | grain |

| Donitory program | |
|------------------------------|--|
| Equipment supplied | Door coupling rotary handle with rotary drive Add-on rotary handle on switch with "Deliberate Action" operation as per NFPA79 and UL508A Part 2 NZM1/2-XV4 shaft extension for mounting depth of 400 mm External warning plate/marking plate in German/English Black and yellow lightning symbol |
| Product range | Accessories |
| Accessories | Main switch assembly kit |
| Standard/Approval | UL/CSA, IEC |
| Construction size | NZM1 |
| Description | Kit for use as a main switch |
| Function | With red door coupling rotary handle for use of switch as emergency switching off device |
| Protection class | IP66 UL/CSA Type 4X, Type 12 |
| Locking facility | lockable on the 0 position on the switch using up to 3 padlocks |
| Door interlock | Door interlock on OFF with max. 3 padlocks With activated door interlock. Cannot be opened in ON, OFF, or TRIP. Can only be opened in RESET. Can be modified such that it can be defeated from the outside using a screwdriver Not defeated in the locked OFF position. |
| Project planning information | External warning plate/designation label can be clipped on. For enhanced busbar tag shroud on the incomer side, please order IP2X protection against contact with a finger. |
| For use with | NZM1(-4) PN1(-4), N(S)1(-4) |

Design verification as per IEC/EN 61439

| C/EN 61439 design verification | |
|--|---|
| 10.2 Strength of materials and parts | |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton w provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must observed. |

| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
|-------------------------------------|--|
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |


Technical data ETIM 6.0

| Low-voltage industrial components (EG000017) / Handle for power circuit breaker (EC000229) Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Handle for switch devices (ecl@ss8.1-27-37-04-14 [AKF012011]) | | | | |
|---|-----|--|--|--|
| | | | | |
| Colour | Red | | | |
| Suitable for emergency stop | Yes | | | |
| With axe | Yes | | | |
| Suitable for power circuit breaker | Yes | | | |
| Suitable for switch disconnector | Yes | | | |

Approvals

| Product Standards | UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking |
|--------------------------------------|---|
| UL File No. | E140305 |
| UL Category Control No. | DIHS |
| CSA File No. | 022086 |
| CSA Class No. | 1437-01 |
| North America Certification | UL listed, CSA certified |
| Specially designed for North America | Designed as operating handle for Supply Circuit Disconnecting Means. Rotary handle with additional 4th position, beyond OFF, to release door interlock. UL 508A, NFPA 79, Industrial Machinery. |
| Degree of Protection | IEC: IP66, UL/CSA Type 4X, 12 |

Dimensions



Additional product information (links)

IL01219045Z (AWA1230-2527) Door coupling rotary handle, version for North America

IL01219045Z (AWA1230-2527) Door coupling rotary handle, version for North America

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL01219045Z2015_02.pdf