

## Residual current circuit-breaker, 63A, 4pole, 300mA, type U

Powering Business Worldwide\*

Part no. PFIM-63/4/03-U Article no. 235747

Similar to illustration

	Del	ivery	progr	am
--	-----	-------	-------	----

71 0			
Basic function			Residual current circuit breakers
Number of poles			4 pole
Application			Residual current circuit-breaker - frequency converter-proof
Rated current	In	Α	63
Rated short-circuit strength	I <sub>cn</sub>	kA	10
Rated fault current	$I_{\Delta N}$	Α	0.3
Туре			Type U
Tripping		Α	selective switch off
Product range			PFIM
Sensitivity			pulse-current sensitive, suitable for variable frequency drives
Impulse withstand current			surge-proof 5 kA

# **Technical data**

#### **Electrical**

Sensitivity			pulse-current sensitive, suitable for variable frequency drives
Rated short-circuit strength	I <sub>cn</sub>	kA	10

# **Design verification as per IEC/EN 61439**

Design verification as per IEG/EN 61439			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	63
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	10.5
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
			Starting at 40 °C, the max. permissible continuous current decreases by 3% for every 1 °C
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.

10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 6.0**

Technical data Ethii 0.0			
Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)			
Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss8.1-27-14-22-01 [AAB906011])			
Number of poles		4	
Nominal rated voltage	V	400	
Nominal rated current	А	63	
Rated fault current	А	0.3	
Mounting method		DIN rail	
Leakage current type			
Selective protection		Yes	
Short-circuit breaking capacity (Icw)	kA	10	
Surge current capacity	kA	5	
Frequency		50 Hz	
Additional equipment possible		Yes	
Degree of protection (IP)		IP20	
Construction size (in accordance with DIN 43880)		1	
Width in number of modular spacings		4	
Built-in depth	mm	70.5	
Short-time delayed tripping		No	