

Motor-protective circuit-breaker, 3p+1N/0+1N/C, Ir=0.63-1A, screw connection, large packaging



Part no. PKZM0-1/NHI11-GVP Article no. 039439 XTPR001BC1NLSA11BP Catalog No.

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|---|-------------------|---|--|
| Rated operational current for specified heat dissipation | In | А | 1 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 5.33 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| EC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

| Low-voltage industrial components | /EC000017\ / Motor | nrotaction circuit broo | (or /EC000074) |
|-----------------------------------|-------------------------|-------------------------|----------------|
| Low-voilage industrial components | (EGUUUU I /) / IVIULUI | protection circuit-brea | KEI (EGUUUU/4) |

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Motor protection circuit-breaker (ecl@ss8.1-27-37-04-01

| [AGZ529013]) | | | | |
|--|----|------------------|--|--|
| Overload release current setting | А | 0.63 - 1 | | |
| Adjustment range undelayed short-circuit release | Α | 15.5 - 15.5 | | |
| Thermal protection | | No | | |
| Phase failure sensitive | | Yes | | |
| Switch off technique | | Thermomagnetic | | |
| Rated operating voltage | V | 690 - 690 | | |
| Rated permanent current lu | Α | 1 | | |
| Rated operation power at AC-3, 230 V | kW | 0.12 | | |
| Rated operation power at AC-3, 400 V | kW | 0.25 | | |
| Type of electrical connection of main circuit | | Screw connection | | |
| Type of control element | | Turn button | | |

| Device construction | | Built-in device fixed built-in technique |
|--|----|--|
| With integrated auxiliary switch | | Yes |
| With integrated under voltage release | | No |
| Number of poles | | 3 |
| Rated short-circuit breaking capacity Icu at 400 V, AC | kA | 150 |
| Degree of protection (IP) | | IP20 |
| Height | mm | 93 |
| Width | mm | 54 |
| Depth | mm | 76 |