

Motor-protective circuit-breaker, 3p+1N/O+1N/C, Ir=1.6-2.5A, screw connection, large packaging



Part no. Article no. Catalog No. PKZM0-2,5/NHI11-GVP 039437 XTPR2P5BC1NLSA11BP

Design verification as per IEC/EN 61439

| In | А | 2.5 |
|-------------------|------------------|--|
| P _{vid} | W | 5.16 |
| P _{diss} | W | 0 |
| | | |
| | | |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | P _{vid} | P _{vid} W |

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Motor protection circuit-breaker (EC000074)

| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Motor protection circuit-breaker (ecl@ss8.1-27-37-04-01 [AGZ529013]) | | | | |
|--|----|------------------|--|--|
| Overload release current setting | А | 1.6 - 2.5 | | |
| Adjustment range undelayed short-circuit release | А | 39 - 39 | | |
| Thermal protection | | No | | |
| Phase failure sensitive | | Yes | | |
| Switch off technique | | Thermomagnetic | | |
| Rated operating voltage | V | 690 - 690 | | |
| Rated permanent current lu | А | 2.5 | | |
| Rated operation power at AC-3, 230 V | kW | 0.37 | | |
| Rated operation power at AC-3, 400 V | kW | 0.75 | | |
| Type of electrical connection of main circuit | | Screw connection | | |
| Type of control element | | Turn button | | |
| | | | | |

| Device construction | | Built-in device fixed built-in technique |
|--|----|--|
| With integrated auxiliary switch | | Yes |
| With integrated under voltage release | | No |
| Number of poles | | 3 |
| Rated short-circuit breaking capacity Icu at 400 V, AC | kA | 150 |
| Degree of protection (IP) | | IP20 |
| Height | mm | 93 |
| Width | mm | 54 |
| Depth | mm | 76 |