



Part no. Article no. PLHT-C50/3N 248063

## Similar to illustration

| Delivery program  |                   |    |  |
|---|-------------------|----|--|
| Basic function  |                   |    | Miniature circuit breakers   |
| Number of poles   |                   |    | 3 pole+N   |
| Tripping characteristic   |                   |    | С  |
| Application   |                   |    | Switchgear for industrial and advanced commercial applications   |
| Rated current   | l <sub>n</sub>    | A  | 50   |
| Rated switching capacity acc. to IEC/EN 60947-2   |                   | kA | 25   |
| Product range   |                   |    | PLHT   |
| Technical data<br>Electrical  |                   |    |  |
| Rated switching capacity acc. to IEC/EN 60947-2   |                   | kA | 25   |
| Design verification as per IEC/EN 61439   |                   |    |  |
| Technical data for design verification  |                   |    |  |
| Rated operational current for specified heat dissipation  | I <sub>n</sub>    | A  | 50   |
| Heat dissipation per pole, current-dependent  | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub>  | W  | 15.93  |
| Static heat dissipation, non-current-dependent  | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity   | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.  | 0133              | °C | -25  |
| Operating ambient temperature max.  |                   | °C | 55   |
|   |                   |    | linear, per +1 °C, results in a 0.35% reduction of current carrying capacity   |
| IEC/EN 61439 design verification  |                   |    | ,  |
| 10.2 Strength of materials and parts  |                   |    |  |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat<br>and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |                   |    |  |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 6.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011]) |    |         |  |  |
|--|----|---------|--|--|
| Release characteristic   |    | C       |  |  |
| Number of poles (total)  |    | 4       |  |  |
| Number of protected poles  |    | 4       |  |  |
| Nominal rated current  | А  | 50      |  |  |
| Nominal rated voltage  | V  | 400     |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  | kA | 25      |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  | kA | 25      |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V   | kA | 0       |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   | kA | 0       |  |  |
| Voltage type   |    | AC      |  |  |
| Current limiting class   |    | 3       |  |  |
| Frequency  | Hz | 50 - 60 |  |  |
| Concurrently switching N-neutral   |    | Yes     |  |  |
| Suitable for flush-mounted installation  |    | No      |  |  |
| Over voltage category  |    | 3       |  |  |
| Pollution degree   |    | 2       |  |  |
| Width in number of modular spacings  |    | 6       |  |  |
| Built-in depth   | mm | 75      |  |  |
| Additional equipment possible  |    | Yes     |  |  |
| Degree of protection (IP)  |    | IP20    |  |  |