

Illuminated selector switch actuator, 3 positions, green, maintained



Part no. Q18LWK3R1-GN Article no. 072330 Catalog No. Q18LWK3R1-GN

Delivery program

| Don'tory program | |
|----------------------------|---|
| Product range | RMQ16 |
| Basic function | Illuminated selector switch actuator |
| Single unit/Complete unit | Single unit |
| Design | With thumb-grip |
| | maintained/momentary |
| Function: | |
| | 45° 🕩 45° |
| Description | with VS anti-rotation tab without light elements With base, W2x4,6d; max. 30 V, 1 W |
| | 3 positions |
| Colour | |
| Thumb-grip | green |
| | |
| Degree of Protection | IP65 |
| Connection to SmartWire-DT | no |
| Front dimensions | 18 × 18 mm |
| | |

Technical data

General

| General | | | |
|---------------------------------------|----------------|-------------------|--|
| Standards | | | IEC/EN 60947 |
| Lifespan, mechanical | Operations | x 10 ⁶ | >3 |
| Operating frequency | Operations/h | | ≤ ₁₈₀₀ |
| Operating torque | | Nm | ≦ _{0.2} |
| Degree of protection, IEC/EN 60529 | | | IP65 |
| Climatic proofing | | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature | | | |
| Open | | °C | -25 - +60 |
| Enclosed | | °C | - 25 - 40 |
| Mounting position | | | As required |
| Mechanical shock resistance | | g | > 40 according to IEC 60068-2-27 Shock duration 11 ms Sinusoidal |
| Terminal capacities | | mm ² | 0.5 - 1.0 |
| Blade terminal | | | 2.8 x 0.8 mm to DIN 46244 |
| Fast-on connectors | | | 2.8 x 0.8 mm to DIN 46247 and IEC 60760 |
| Contacts | | | |
| Rated impulse withstand voltage | U_{imp} | V AC | 800 |
| Rated insulation voltage | Ui | V | 250 |
| Overvoltage category/pollution degree | | | III/3 |
| Rated operational voltage | U _e | V AC | 24 |
| Control circuit reliability | | | |

| at 24 V DC/5 mA | H _F | Fault probability | < 10 ⁻⁷ (i.e. 1 failure to 10 ⁷ operations) |
|----------------------------------|----------------|----------------------|--|
| at 5 V DC/1 mA | H _F | Fault probabilit | $< 5 \times 10^{-6}$ (1 failure in 5×10^{6} operations) |
| Use of insulated ferrule ISH 2,8 | | | >24 V AC/DC recommended >50 V AC or 120 V DC is mandatory, even on unused blade terminals |

Design verification as per IEC/EN 61439

| In | Α | 0 |
|-------------------|---|--|
| P _{vid} | W | 0 |
| P _{vid} | W | 0 |
| P _{vs} | W | 0 |
| P _{diss} | W | 0 |
| | °C | -25 |
| | °C | 60 |
| | | |
| | | |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Please enquire |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | Not applicable. |
| | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | P _{vid} P _{vid} P _{vs} | P _{vid} W P _{vid} W P _{vs} W P _{diss} W °C °C |

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss8.1-27-37-12-13


| [AKF031011]) | ii teciiilology / coi | illillalla c | and didnii device / 11011 eleilletit 101 selector switches (ethesso.1-27-07-12-15 |
|----------------------------|-----------------------|--------------|---|
| Number of switch positions | | | 3 |
| Type of control element | | | Toggle |
| Suitable for illumination | | | Yes |
| Colour control element | | | Black |
| Colour indicator light cap | | | Green |
| Construction type lens | | | Square |
| Hole diameter | m | ım | 16 |
| Width opening | m | ım | 0 |
| Height meter opening | m | ım | 0 |

| Switching function latching | Yes |
|---------------------------------------|---------|
| Spring-return | Yes |
| Degree of protection (IP), front side | IP65 |
| With front ring | Yes |
| Material front ring | Plastic |
| Colour front ring | Black |

Approvals

| Product Standards | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CE marking |
|-----------------------------|---|
| UL File No. | E29184 |
| UL Category Control No. | NKCR |
| CSA File No. | 46552 |
| CSA Class No. | 3211-03 |
| North America Certification | UL listed, CSA certified |
| Degree of Protection | UL/CSA Type 1 |

Dimensions



oqual o otylo

Additional product information (links)

IL04716016Z (AWA1160-1429) Mounting of components

IL04716016Z (AWA1160-1429) Mounting of components

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716016Z2011_03.pdf