

Illuminated selector switch actuator, 3 positions, white, momentary, +filament lamp 24V $\,$



Part no. Q25LWK3-WS/WB Article no. 072346 Catalog No. Q25LWK3-WS-WB

Delivery program

Product range	RMQ16
Basic function	Illuminated selector switch actuator
Single unit/Complete unit	Single unit
Design	With thumb-grip
	momentary
Function:	
	45° 🕩 45°
Description	with VS anti-rotation tab with filament bulb, 24 V
	3 positions
Colour	
Thumb-grip	White
Degree of Protection	IP65
Connection to SmartWire-DT	no
Front dimensions	25 × 25 mm

Technical data

Overvoltage category/pollution degree

Rated operational voltage

Control circuit reliability

General

General			
Standards			IEC/EN 60947
Lifespan, mechanical	Operations	x 10 ⁶	>3
Operating frequency	Operations/h		≦ ₁₈₀₀
Operating torque		Nm	≦ _{0.2}
Degree of protection, IEC/EN 60529			IP65
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature			
Open		°C	-25 - +60
Enclosed		°C	- 25 - 40
Mounting position			As required
Mechanical shock resistance		g	> 40 according to IEC 60068-2-27 Shock duration 11 ms Sinusoidal
Terminal capacities		mm ²	0.5 - 1.0
Blade terminal			2.8 x 0.8 mm to DIN 46244
Fast-on connectors			2.8 x 0.8 mm to DIN 46247 and IEC 60760
Contacts			
Rated impulse withstand voltage	U_{imp}	V AC	800
Rated insulation voltage	Ui	V	250

Ue

III/3

24

V AC

at 24 V DC/5 mA	H _F	Fault probability	< 10 ⁻⁷ (i.e. 1 failure to 10 ⁷ operations)
at 5 V DC/1 mA	H _F	Fault probability	< 5 x 10 ⁻⁶ (1 failure in 5 x 10 ⁶ operations)
Use of insulated ferrule ISH 2,8			>24 V AC/DC recommended >50 V AC or 120 V DC is mandatory, even on unused blade terminals

Design verification as per IEC/EN 61439

In	Α	0
P _{vid}	W	0
P _{vid}	W	0
P _{vs}	W	1
P _{diss}	W	0
	°C	-25
	°C	60
		Meets the product standard's requirements.
		Meets the product standard's requirements.
		Meets the product standard's requirements.
		Meets the product standard's requirements.
		Please enquire
		Does not apply, since the entire switchgear needs to be evaluated.
		Does not apply, since the entire switchgear needs to be evaluated.
		Meets the product standard's requirements.
		Does not apply, since the entire switchgear needs to be evaluated.
		Meets the product standard's requirements.
		Does not apply, since the entire switchgear needs to be evaluated.
		Does not apply, since the entire switchgear needs to be evaluated.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
		Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specification}$
		Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
	P _{vid} P _{vid}	P _{vid} W P _{vid} W P _{vs} W P _{diss} W °C

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)


[AKF031011])		
Number of switch positions		3
Type of control element		Toggle
Suitable for illumination		Yes
Colour control element		Black
Colour indicator light cap		White
Construction type lens		Square
Hole diameter	mm	16
Width opening	mm	0

Height meter opening	mm	0
Switching function latching		No
Spring-return		Yes
Degree of protection (IP), front side		IP65
With front ring		Yes
Material front ring		Plastic
Colour front ring		Black

Approvals

Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	46552
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type 1

Dimensions



Additional product information (links)

IL04716016Z (AWA1160-1429) Mounting of components

IL04716016Z (AWA1160-1429) Mounting of components

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716016Z2011_03.pdf