

Key-operated actuator, 3 positions, black, maintained

Powering Business Worldwide*

Part no. Q25S3R-A4
Article no. 072382
Catalog No. Q25S3R-A4

	IIIO	I DE	aram
	IIVEI	V 111	

Product range	F	RMQ16
Basic function	l	Key-operated buttons
Single unit/Complete unit	:	Single unit
Design	H	Key operated
	r	maintained/momentary
Function:		
	4	45° \ 45°
	3	3 positions
Key withdrawable in position		
	I	I
	(0
Degree of Protection	I	IP65
Front ring	١	without bezel
Connection to SmartWire-DT	r	no
Front dimensions	F	Front dimensions 25 × 25 mm
Information about equipment supplied	\	With 1 key

Technical data

General

deliciai			
Standards			IEC/EN 60947
Lifespan, mechanical	Operations	x 10 ⁶	>3
Operating frequency	Operations/h		≤ ₁₈₀₀
Operating torque		Nm	≤ _{0.4}
Degree of protection, IEC/EN 60529			IP65
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature			
Open		°C	-25 - +60
Enclosed		°C	- 25 - 40
Mounting position			As required
Mechanical shock resistance		g	> 40 according to IEC 60068-2-27 Shock duration 11 ms Sinusoidal
Terminal capacities		mm ²	0.5 - 1.0
Blade terminal			2.8 x 0.8 mm to DIN 46244
Fast-on connectors			2.8 x 0.8 mm to DIN 46247 and IEC 60760
Contacts			
Rated impulse withstand voltage	U_{imp}	V AC	800
			250

Contacts			
Rated impulse withstand voltage	U_{imp}	V AC	800
Rated insulation voltage	Ui	V	250
Overvoltage category/pollution degree			III/3
Rated operational voltage	U _e	V AC	24
Control circuit reliability			
at 24 V DC/5 mA	H _F	Fault probabilit	< 10 ⁻⁷ , < 1 failure in 10 ⁷ operations
at 5 V DC/1 mA	H _F	Fault probabilit	$< 5 \times 10^{-6}$, < 1 failure in 5×10^{6} operations
Use of insulated ferrule ISH 2,8			On >24 V AC/DC recommended On >50 V AC or 120 V DC mandatory, also on unoccupied blade terminals

Design verification	as per	IEC/EN	61439
---------------------	--------	--------	-------

Technical data for design verification

Rated operational current for specified heat dissipation	In	Α	0
Heat dissipation per pole, current-dependent	P _{vid}	W	0
Equipment heat dissipation, current-dependent	P _{vid}	W	0
Static heat dissipation, non-current-dependent	P _{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	60
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $ \frac{1}{2} \left(\frac{1}{2} \right) = \frac{1}{2} \left(\frac{1}{2} \right) \left($			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Please enquire
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			Not applicable.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0


Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss8.1-27-37-12-13 [AKF031011])

Number of switch positions Type of control element Suitable for illumination Colour control element Colour control element Colour indicator light cap Construction type lens Hole diameter Midth opening Height meter opening Switching function latching Spring-return Degree of protection (IP), front side With front ring Material front ring Colour font ring Colour font ring Siable Key No No Not applicable Not applicable Square	[AKF031011])			
Suitable for illumination Colour control element Colour indicator light cap Construction type lens Hole diameter Width opening Height meter opening Switching function latching Spring-return Degree of protection (IP), front side Material front ring Mo Black Not applicable Square Not applicable Square Mm 16 Wit applicable Square Mm 0 Colour indicable No Pes Plastic	Number of switch positions			3
Colour control element Colour indicator light cap Construction type lens Hole diameter Midth opening	Type of control element			Key
Colour indicator light cap Construction type lens Hole diameter mm 16 Width opening mm 0 Height meter opening mm 0 Switching function latching Spring-return Degree of protection (IP), front side With front ring Material front ring Not applicable Square No 0 No 16 No 19 No Plastic	Suitable for illumination			No
Construction type lens Hole diameter mm 16 Width opening mm 0 Height meter opening mm 0 Switching function latching Spring-return Degree of protection (IP), front side With front ring Material front ring Square No Plastic	Colour control element			Black
Hole diameter mm 16 Width opening mm 0 Height meter opening mm 0 Switching function latching Yes Spring-return No Degree of protection (IP), front side IP65 With front ring Yes Material front ring Plastic	Colour indicator light cap			Not applicable
Width openingmm0Height meter openingmm0Switching function latchingYesSpring-returnNoDegree of protection (IP), front sideIP65With front ringYesMaterial front ringPlastic	Construction type lens			Square
Height meter opening mm 0 Switching function latching Yes Spring-return No Degree of protection (IP), front side IP65 With front ring Yes Material front ring Plastic	Hole diameter	m	nm	16
Switching function latching Yes Spring-return No Degree of protection (IP), front side IP65 With front ring Yes Material front ring Plastic	Width opening	m	nm	0
Spring-return Degree of protection (IP), front side With front ring Yes Material front ring Plastic	Height meter opening	m	nm	0
Degree of protection (IP), front side IP65 With front ring Yes Material front ring Plastic	Switching function latching			Yes
With front ring Yes Material front ring Plastic	Spring-return			No
Material front ring Plastic	Degree of protection (IP), front side			IP65
	With front ring			Yes
Colour front ring Black	Material front ring			Plastic
	Colour front ring			Black

Approvals	
Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	46552
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type 1

Dimensions



Additional product information (links)

IL04716016Z (AWA1160-1429) Mounting of components

IL04716016Z (AWA1160-1429) Mounting of components

 $ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716016Z2011_03.pdf$