

1607774

https://www.phoenixcontact.com/us/products/1607774

Please be informed that the data shown in this PDF document is generated from our online catalog. Please find the complete data in the user documentation. Our general terms of use for downloads are valid.



Panel mounting frames, Range of articles: VARIOCON, design: VC2, housing material: Polyamide. Required for supporting base elements and voltages > 42 V

### Commercial data

Item number	1607774
Packing unit	1 pc
Minimum order quantity	1 pc
Sales key	AB01
Product key	ABLABC
Catalog page	Page 30 (C-2-2013)
GTIN	4017918948894
Weight per piece (including packing)	28.8 g
Weight per piece (excluding packing)	28.7 g
Customs tariff number	85389099
Country of origin	PL



https://www.phoenixcontact.com/us/products/1607774



### Technical data

#### Notes

may damage persons and/or property.  • WARNING: Commission property functioning products only. The products must be regularly inspected for damage. Decommission defective products immediately. Replace damaged products. Repairs are not possible.  • WARNING: Only electrically qualified personnel may install a operate the product. They must observe the following safety notes. The qualified personnel may familiar with the basic electrical engineering. They must be able to recognize and prevent danger. The relevant symbol on the packaging indical that only personnel familiar with electrical engineering are allowed to install and operate the product.  • The products are suitable for applications in plant, controller and electrical device engineering.  • When operating the connectors in outdoor applications, they must be separately protected against environmental influence.  • Assembled products may not be manipulated or improperly opened.  • Only use mating connectors that are specified in the technic data of the standards listed (e.g., the ones listed in the product accessories online at phoenixcontact.com/products).  • When using the product in direct connection with third-party manufacturers, the user is responsible.  • For operating voltages > 50 V AC, conductive connector housings must be grounded  • Ensure that the protective or functional ground has been properly connected.  • VDE 0100/1.97 § 414.1.3.2 and DIN EN 60 204/11.98 § 14. are applicable when combining several circuits in a cable and connector  • Observe the corresponding technical data. You will find information:  • On the product  • On the product on interestical products under the product  • Only use tools recommended by Phoenix Contact  • The installation notes/Design In documents online on the download agae at phoenix contact com/products must be observed for this product.	lotes	
WARNING: The connectors may not be plugged in or disconnected under load. Ignoring the warning or improper us may damage persons and/or property.  **WARNING: Commission property functioning products only. The products must be regularly inspected for damage. Decommission defective products immediately. Replace damaged products. Repairs are not possible.  **WARNING: Only electrically qualified personnel may install operate the product. They must be stemiliar with the basic electrical engineering. They must be the recognize and prevent danger. The relevant symbol on the packaging indicat that only personnel familiar with electrical engineering. They must be abrical engineering are allowed to install and operate the product.  **The products are suitable for applications in plant, controller, and electrical device engineering.  **When operating the connectors in outdoor applications, they must be separately protected against environmental influence.  **Assembled products may not be manipulated or improperly opened.  **Only use mating connectors that are specified in the technic data of the standards listed (e.g., the ones listed in the product accessories online at phoenixcontact com/products).  **When using the product in direct connection with third-party manufacturers, the user is responsible.  **For operating voltages > 50 V AC, conductive connector housings must be grounded  **Ensure that the protective or functional ground has been properly connected.  **VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14: are applicable when combining several circuits in a cable and connector  **Observe the corresponding technical data. You will find information:  **On the packing label  **on the product  **Only use tools recommended by Phoenix Contact  **The inst	General	Required for supporting base elements and voltages > 42 V
disconnected under load. Ignoring the warning or improper us may damage persons and/or property.  • WARNING: Commission properly functioning products only. The products must be regularly inspected for damage. Decommission defective products immelsed admaged products. Repairs are not possible.  • WARNING: Only electrically qualified personnel may install a operate the product. They must observe the following safety notes. The qualified personnel must be familiar with the basic electrical engineering. They must be bate for ecognize and prevent danger. The relevant symbol on the packagin indicat that only personnel familiar with electrical engineering are allowed to install and operate the product.  • The products are suitable for applications in plant, controller, and electrical device engineering.  • When operating the connectors in outdoor applications, they must be separately protected against environmental influence.  • Assembled products may not be manipulated or improperty opened.  • Only use mating connectors that are specified in the technic data of the standards listed (e.g., the ones listed in the product cata of the standards listed (e.g. the ones listed in the product accessories online at phoenixcontact.com/products).  • When using the product in direct connection with third-party manufacturers, the user is responsible.  • For operating voltages > 50 V AC, conductive connector housings must be grounded  • Ensure that the protective or functional ground has been properly connected.  • VDE 0100/1.97 § 411.1.3. 2 and DIN EN 60 204/11.98 § 14. are applicable when combining several circuits in a cable and connector  • Observe the corresponding technical data. You will find information:  • On the product  • On the packing label  • In the supplied documentation  • Online at phoenixcontact.com/products under the product  • Only use tools recommended by Phoenix Contact  • The installation notes/Design in documents online on the download page at phoenixcontact connectors that are not in us the suitable accesso	Safety note	
The products must be regularly inspected for damage. Decommission defective products immediately. Replace damaged products. Repairs are not possible.  *WARNING: Only electrically qualified personnel may install a operate the product. They must observe the following safety notes: The qualified personnel must be familiar with the basic electrical engineering. They must be able to recognize and prevent danger. The relevant symbol on the packaging indicat that only personnel familiar with electrical engineering are allowed to install and operate the product.  *The products are suitable for applications in plant, controller and electrical device engineering.  *When operating the connectors in outdoor applications, they must be separately protected against environmental influence  *Assembled products may not be manipulated or improperly opened.  Only use mating connectors that are specified in the technic data of the standards listed (e.g., the ones listed in the product accessories online at phoenixcontact.com/products).  *When using the product in direct connection with third-party manufacturers, the user is responsible.  *For operating voltages > 50 V AC, conductive connector housings must be grounded  *Ensure that the protective or functional ground has been properly connected.  *VDE o1001.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14. are applicable when combining several circuits in a cable and connector  *Observe the corresponding technical data. You will find information:  On the product  On the product  On the product  The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.	Safety note	disconnected under load. Ignoring the warning or improper use
operate the product. They must observe the following safety notes. The qualified personnel must be familiar with the basic electrical engineering. They must be able to recognize and prevent danger. The relevant symbol on the packaging indicat that only personnel familiar with electrical engineering are allowed to install and operate the product.  • The products are suitable for applications in plant, controller and electrical device engineering.  • When operating the connectors in outdoor applications, they must be separately protected against environmental influence.  • Assembled products may not be manipulated or improperly opened.  • Only use mating connectors that are specified in the technic data of the standards listed (e.g. the ones listed in the product accessories online at phoenixcontact.com/products).  • When using the product in direct connection with third-party manufacturers, the user is responsible.  • For operating voltages > 50 V AC, conductive connector housings must be grounded  • Ensure that the protective or functional ground has been properly connected.  • VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.3 are applicable when combining several circuits in a cable and connector  • Observe the corresponding technical data. You will find information:  o On the packing label  o In the supplied documentation  o Online at phoenixcontact.com/products under the product  • Only use tools recommended by Phoenix Contact  • The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  • Use a protective cap to protect connectors that are not in us. The suitable accessories are available online in the accessory.		The products must be regularly inspected for damage.  Decommission defective products immediately. Replace
and electrical device engineering.  When operating the connectors in outdoor applications, they must be separately protected against environmental influence  Assembled products may not be manipulated or improperly opened.  Only use mating connectors that are specified in the technic data of the standards listed (e.g., the ones listed in the product accessories online at phoenixcontact.com/products).  When using the product in direct connection with third-party manufacturers, the user is responsible.  For operating voltages > 50 V AC, conductive connector housings must be grounded  Ensure that the protective or functional ground has been properly connected.  VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.3 are applicable when combining several circuits in a cable and connector  Observe the corresponding technical data. You will find information:  o On the product o On the product o On the packing label o In the supplied documentation o Online at phoenixcontact.com/products under the product Only use tools recommended by Phoenix Contact  The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  Use a protective cap to protect connectors that are not in us The suitable accessories are available online in the accessory		notes. The qualified personnel must be familiar with the basics of electrical engineering. They must be able to recognize and prevent danger. The relevant symbol on the packaging indicates that only personnel familiar with electrical engineering are
must be separately protected against environmental influence  Assembled products may not be manipulated or improperly opened.  Only use mating connectors that are specified in the technic data of the standards listed (e.g. the ones listed in the product accessories online at phoenixcontact.com/products).  When using the product in direct connection with third-party manufacturers, the user is responsible.  For operating voltages > 50 V AC, conductive connector housings must be grounded  Ensure that the protective or functional ground has been properly connected.  VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.1 are applicable when combining several circuits in a cable and connector  Observe the corresponding technical data. You will find information:  o On the product o On the packing label on the supplied documentation o Online at phoenixcontact.com/products under the product  Only use tools recommended by Phoenix Contact  The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  Use a protective cap to protect connectors that are not in us The suitable accessories are available online in the accessories		<ul> <li>The products are suitable for applications in plant, controller, and electrical device engineering.</li> </ul>
opened.  Only use mating connectors that are specified in the technic data of the standards listed (e.g. the ones listed in the product accessories online at phoenixcontact.com/products).  When using the product in direct connection with third-party manufacturers, the user is responsible.  For operating voltages > 50 V AC, conductive connector housings must be grounded  Ensure that the protective or functional ground has been properly connected.  VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.3 are applicable when combining several circuits in a cable and connector  Observe the corresponding technical data. You will find information:  On the product On the product On the packing label On the packing label On the packing label On the product Online at phoenixcontact.com/products under the product The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  Use a protective cap to protect connectors that are not in us. The suitable accessories are available online in the accessory.		<ul> <li>When operating the connectors in outdoor applications, they must be separately protected against environmental influences.</li> </ul>
data of the standards listed (e.g. the ones listed in the product accessories online at phoenixcontact.com/products).  • When using the product in direct connection with third-party manufacturers, the user is responsible.  • For operating voltages > 50 V AC, conductive connector housings must be grounded  • Ensure that the protective or functional ground has been properly connected.  • VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.1 are applicable when combining several circuits in a cable and connector  • Observe the corresponding technical data. You will find information:  • On the product • On the product • On the packing label • In the supplied documentation • Online at phoenixcontact.com/products under the product • Only use tools recommended by Phoenix Contact  • The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  • Use a protective cap to protect connectors that are not in us. The suitable accessories are available online in the accessory.		
manufacturers, the user is responsible.  For operating voltages > 50 V AC, conductive connector housings must be grounded  Ensure that the protective or functional ground has been properly connected.  VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.1 are applicable when combining several circuits in a cable and connector  Observe the corresponding technical data. You will find information:  On the product On the packing label In the supplied documentation Online at phoenixcontact.com/products under the product Only use tools recommended by Phoenix Contact  The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  Use a protective cap to protect connectors that are not in ust The suitable accessories are available online in the accessory.		<ul> <li>Only use mating connectors that are specified in the technical data of the standards listed (e.g. the ones listed in the product accessories online at phoenixcontact.com/products).</li> </ul>
housings must be grounded  • Ensure that the protective or functional ground has been properly connected.  • VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.3 are applicable when combining several circuits in a cable and connector  • Observe the corresponding technical data. You will find information:  o On the product o On the packing label o In the supplied documentation o Online at phoenixcontact.com/products under the product • Only use tools recommended by Phoenix Contact  • The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  • Use a protective cap to protect connectors that are not in use The suitable accessories are available online in the accessory.		
properly connected.  • VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.1 are applicable when combining several circuits in a cable and connector  • Observe the corresponding technical data. You will find information:  o On the product  o On the packing label  o In the supplied documentation  o Online at phoenixcontact.com/products under the product  • Only use tools recommended by Phoenix Contact  • The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  • Use a protective cap to protect connectors that are not in use The suitable accessories are available online in the accessory.		
are applicable when combining several circuits in a cable and connector  Observe the corresponding technical data. You will find information: On the product On the packing label On the supplied documentation Online at phoenixcontact.com/products under the product Only use tools recommended by Phoenix Contact The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.  Use a protective cap to protect connectors that are not in use The suitable accessories are available online in the accessory		
information: o On the product o On the packing label o In the supplied documentation o Online at phoenixcontact.com/products under the product • Only use tools recommended by Phoenix Contact • The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product. • Use a protective cap to protect connectors that are not in use The suitable accessories are available online in the accessory		VDE 0100/1.97 § 411.1.3.2 and DIN EN 60 204/11.98 § 14.1.3 are applicable when combining several circuits in a cable and/or connector
<ul> <li>The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.</li> <li>Use a protective cap to protect connectors that are not in uso The suitable accessories are available online in the accessory.</li> </ul>		information: o On the product o On the packing label o In the supplied documentation
download page at phoenixcontact.com/products must be observed for this product.  • Use a protective cap to protect connectors that are not in use The suitable accessories are available online in the accessory		Only use tools recommended by Phoenix Contact
The suitable accessories are available online in the accessory		download page at phoenixcontact.com/products must be
section of the product at procent contributions		<ul> <li>Use a protective cap to protect connectors that are not in use.</li> <li>The suitable accessories are available online in the accessory section of the product at phoenixcontact.com/products</li> </ul>

• Operate the connector only when it is fully plugged in.



1607774

https://www.phoenixcontact.com/us/products/1607774

<ul> <li>Ensure that when laying the cable, the tensile load on the connectors does not exceed the upper limit specified in the standards.</li> </ul>
<ul> <li>Observe the minimum bending radius of the cable. Lay the cable without twisting it.</li> </ul>
<ul> <li>The connector warms up in normal operation. Depending on the ambient conditions, the surface of the connector can continue to warm up. In this case, the user is responsible for posting warnings (e.g. DIN EN ISO 13732-1:2008-12).</li> </ul>

### Product properties

Туре	VC2
Product type	Panel mounting frame
Product family	VARIOCON
Number of module slots	3
Series	VC-M

### Electrical properties

Contact resistance, inner conductor
-------------------------------------

#### **Dimensions**

Dimensional drawing	51 7,1 65,6
Width	65.6 mm
Height	25.5 mm
Depth	7.1 mm
Length	56.2 mm

### Material specifications

Color of the housing part	black
Material	PA-GF
Material	Polyamide
Flammability rating according to UL 94	V0
Contact material	CuZn
Contact surface material	nickel-plated
Housing material	Polyamide

#### Environmental and real-life conditions

#### Ambient conditions

	Ambient temperature (operation)	-40 °C 125 °C



1607774

https://www.phoenixcontact.com/us/products/1607774

## Classifications

UNSPSC 21.0

#### **ECLASS**

27440210		
27440210		
27440210		
ETIM		
EC002310		

39121400



1607774

https://www.phoenixcontact.com/us/products/1607774

## Environmental product compliance

China RoHS	Environmentally friendly use period: unlimited = EFUP-e
	No hazardous substances above threshold values

Phoenix Contact 2024 © - all rights reserved https://www.phoenixcontact.com

Phoenix Contact USA 586 Fulling Mill Road Middletown, PA 17057, United States (+717) 944-1300 info@phoenixcon.com