

**PAC  
PAC-MIMQ-4X10-V1-1M**

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany  
Fon: +49 5231 14-0  
Fax: +49 5231 14-292083  
www.weidmueller.com



Similar to illustration

The pre-assembled PAC cables establish an electrical and logical connection between the PLC and the TERMSERIES relay modules. These cables consist of the following components:

- Manufacturer's PLC connector.
- Multi-pole LIYY cable with a cross-section of 0.14mm<sup>2</sup>.
- 10-pole flat cable connectors.

The cables are tested automatically for continuity and insulation to ensure the functionality for which they have been designed.

**General ordering data**

Type	PAC-MIMQ-4X10-V1-1M
Order No.	<a href="#">1512310010</a>
Version	Pre-assembled cable, PAC, Cable LiYY, 5.4 ± 1 mm
GTIN (EAN)	4032248236374
Qty.	1 pc(s).

Creation date May 4, 2020 2:21:18 AM CEST

Catalogue status 17.04.2020 / We reserve the right to make technical changes.

## Data sheet

### PAC PAC-MIMQ-4X10-V1-1M

**Weidmüller Interface GmbH & Co. KG**  
 Klingenbergstraße 26  
 D-32758 Detmold  
 Germany  
 Fon: +49 5231 14-0  
 Fax: +49 5231 14-292083  
 www.weidmueller.com

## Technical data

### Dimensions and weights

Net weight	172.8 g
------------	---------

### Temperatures

Operating temperature, max.	50 °C	Operating temperature, min.	-10 °C
Storage temperature, max.	60 °C	Storage temperature, min.	-10 °C
Operating temperature	-10...50 °C	Storage temperature	-10...60 °C

### General Data

Connector PLC side	FUJITSU FCN363J040 40P	Interface connector	4xHE10 10P
Number of poles, min.	10-pole	Outer diameter	5.4 ± 1 mm
Cable	Cable LiYY	Cable length	1 m
Material	PVC	Wire cross-section	0.14 mm <sup>2</sup>

### Electrical Data

Rated voltage (text)	≤ 60 V DC ≤ 25 V AC	Permissible current strength per path, max.	1 A
Total current, max.	3 A	Resistance	≤ 150mΩ/m
High voltage test	1 KV/1s		

### Classifications

ETIM 6.0	EC000237	ETIM 7.0	EC000237
eClass 9.0	27-24-22-20	eClass 9.1	27-24-22-20
eClass 10.0	27-24-22-20		

### Approvals

ROHS	Conform
------	---------