

**PAC**  
**C300-32B-320B-2S-M34-20****Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany  
Fon: +49 5231 14-0  
Fax: +49 5231 14-292083  
www.weidmueller.com

The pre-wired cables allow connecting the Honeywell C300 IOTAs (Input Output Terminal Assemblies) and the Weidmüller FTAs (Field Terminal Assemblies) in a manner that is quick, simple and error free.

The cables may be delivered with single or dual connectors, or even with free ends and end ferrules.

The hood makes it easier to handle and it offers a robust connection with the IOTA. It also allows using cables of different gauge sizes and lengths of up to 50m.

**General ordering data**

Type	C300-32B-320B-2S-M34-20
Order No.	<a href="#">7789888200</a>
Version	Pre-assembled cable, PAC, Cable LiYCY, 0.34 mm <sup>2</sup>
GTIN (EAN)	4032248265763
Qty.	1 pc(s).

Creation date May 1, 2020 9:18:30 AM CEST

Catalogue status 17.04.2020 / We reserve the right to make technical changes.

## Data sheet

### PAC C300-32B-320B-2S-M34-20

**Weidmüller Interface GmbH & Co. KG**  
 Klingenbergstraße 26  
 D-32758 Detmold  
 Germany  
 Fon: +49 5231 14-0  
 Fax: +49 5231 14-292083  
 www.weidmueller.com

## Technical data

### Dimensions and weights

Net weight	4,800 g
------------	---------

### Temperatures

Operating temperature, max.	50 °C	Operating temperature, min.	-10 °C
Storage temperature, max.	60 °C	Storage temperature, min.	-10 °C
Operating temperature	-10...50 °C	Storage temperature	-10...60 °C

### General Data

Connector PLC side	SP-BLZ 5.08 32P with CLAMSHELL	Interface connector	SP-BLZ 5.08 32P with CLAMSHELL
Number of poles, min.	32-pole	Outer diameter	13,9 ± 1 mm
Cable	Cable LiYCY	Cable length	20 m
Material	PVC	Wire cross-section	0.34 mm <sup>2</sup>

### Electrical Data

Rated voltage (text)	≤ 250 Vdc ≤ 250 Vac	Permissible current strength per path, max.	1 A
Total current, max.	4 A	Resistance	≤ 57 mΩ/m
High voltage test	1 KV/1s		

### Classifications

ETIM 6.0	EC000237	ETIM 7.0	EC000237
eClass 9.0	27-24-22-20	eClass 9.1	27-24-22-20
eClass 10.0	27-24-22-20		

### Approvals

Approvals



ROHS

Conform